



**UNDERWRITERS LABORATORIES INC.**

CHICAGO · NORTHBROOK, ILL. · MELVILLE, N.Y. · SANTA CLARA, CALIF.

*an independent, not-for-profit organization testing for public safety*

File R8758  
Project 78NK5345

September 6, 1978

REPORT

on

CABLE RACEWAY PROTECTION SYSTEMS  
FIRE TEST INVESTIGATION

Babcock & Wilcox  
Augusta, Georgia

Copyright © 1978 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above named company to reproduce this Report provided it is reproduced in its entirety.

In no event shall Underwriters Laboratories Inc. be responsible to anyone for whatever use or nonuse is made of the information contained in this Report and in no event shall Underwriters Laboratories, its employees, or its agents incur any obligation or liability for damages, including, but not limited to, consequential damages, arising out of or in connection with the use, or inability to use, the information contained in this Report.

The issuance of this Report in no way implies Listing, Classification, or other Recognition by UL and does not authorize the use of UL Listing or Classification Marks or any other reference to Underwriters Laboratories Inc. on or in connection with the product or system.

GENERALINTRODUCTION:

Concern has been expressed by the Nuclear Regulatory Commission (NRC) for the protection of the circuit integrity of power and control cables in the event of a fire within a nuclear power generating station. Specifically, protection of the redundant control circuits is of interest. In the event of a fire, although control circuits may become inoperative, the protected redundant control circuits should retain their electrical integrity.

The purpose of this investigation was to obtain information on the performance of certain electrical raceway systems protected by ceramic fiber blanket insulation, and perlite-cement insulation, when subjected to a controlled fire exposure. The data obtained are intended for use only by Georgia Power and the Bechtel Corporation for submission only to the Nuclear Regulatory Commission.

The investigation consisted of witnessing four fire tests at the facility of Babcock & Wilcox in Augusta, Georgia. Each test was conducted with one protected cable tray and one protected conduit system as shown in ILLS. 5-8. Each tray was filled with various sizes and types of cables. However, only one size and type of cable was installed into each conduit. All cables were installed forming several circuits to which a low voltage, low current load was applied. Each cable circuit was monitored and the time at which failure (i.e., shorting between conductors, or ground) occurred for each circuit was recorded. Each test varied in fire exposure duration. Details of the installation and test observations and results are recorded herein.

LJP/KWH:plh

D E S C R I P T I O NTEST APPARATUS:

The test furnace employed was a catenary type kiln furnace with a chamber area for the test sample of approximately 36 in. wide, 36 in. deep and 31 in. maximum height, as shown in ILL. 1. Two burners located as shown in ILL. 1 provided the flame source for the furnace.

Furnace operation consisted of mixing natural gas and combustion air (supplied at about 0.6 in. H<sub>2</sub>O pressure) within the burner nozzle. The flame length during<sup>2</sup> normal furnace operation was approximately 18 in. Due to the opposing burning configuration, the hot gases and convective heat swirled upward to the top of the furnace. Combustion products were vented by natural draft through small holes in the fire brick furnace floor and into a vertical stack which was ducted to the outside.

An approximate 24 in. wide by 24 in. high opening was formed into the front and rear fire brick walls of the furnace to accommodate the sample raceways.

TEST SPECIMENS:

Cables - The cables used in this investigation were stranded copper conductors which varied in size and the number of conductors per cable. Both Okolon conductor insulation/Okolon cable jacket, and polyethylene conductor insulation/polyvinyl chloride cable jacket cables were tested. The identification of the cable materials was on the basis of the information provided by the test sponsor. The cable sizes and their identification code for test purposes are shown in Table I.

TABLE I

Identification	Cable Description			Cable Material	
	Number Of Conductors	Conductor Gauge (AWG)	Cross Section Diameter, In.	Conductor Insulation/ Conductor Jacket	Cable Jacket
B1-9	1	9	0.275	Okolon	Okolon
C-19	7	14	0.625	Okolon	Okolon
C-22	19	12	0.965	Okolon	Okolon
C-23	2	12	0.513	Okolon	Okolon
C-24	4	12	0.611	Okolon	Okolon
C-25	7	12	0.725	Okolon	Okolon
C-26	9	12	0.937	Okolon	Okolon
C-27	12	12	1.008	Okolon	Okolon
C-33	4	12	0.934	Okolon	Okolon
+M7-9	7	6	0.935	PE/PVC	PVC

+ - Copper sheathed cable.

Cable Trays - Two types of cable trays were employed in this investigation. In Tests 1 and 4, steel fluted back cable trays were used. The trays were 12 ft long and 18-1/8 in. wide. The tray side channels were 4 in. deep with 3/4 in. flanges, and fabricated from 0.070 in. thick galvanized steel. The 0.055 in. thick galvanized steel fluted back was 15/16 in. deep and formed with 3 in. wide crests and 1 in. wide valleys, with each flute spaced 6 in. O.C. The backing was secured to the side channels with spot welds, and installed with the flutes running perpendicular to the side channels. Also, 5/8 in. diameter, 18 in. long galvanized steel rods were welded 48 in. O.C. to the side channels for additional support.

In the remaining two tests, aluminum open ladder type cable trays were employed. The trays were 12 ft long and 17-3/4 in. wide. The side channels were 4 in. deep with 3/4 in. flanges, and 0.087 in. thick. The U-shaped rungs were 1 in. wide with 1 in. legs and 1/4 in. flanges, and were 0.087 in. thick. The ladder rungs were spaced 9 in. O.C. with each rung welded to each side channel.

Conduit - In two tests 10 ft long, 4 in. diameter schedule 40 galvanized steel pipe with 0.215 in. thick walls was used as rigid metal conduit raceway. In the remaining tests, 4 in. ID diameter aluminum pipe with 0.188 in. thick walls was employed.

Insulation - The insulation installed about the cable tray and conduit raceways (except in Test No. 4) was a 1 in. thick, 9.4 pcf ceramic fiber blanket designated as "Kaowool". The insulation installed about the conduit raceway in Test No. 4 was a 1-1/2 in. thick, 11.8 pcf rigid perlite-cement material designated as "Kaotemp".

Insulation Fasteners - Various different devices were used to temporarily and permanently fasten the insulation about the raceways. One inch wide Scotchgard filament adhesive tape was used to temporarily secure various pieces of the ceramic fiber blanket prior to installation of the permanent fasteners. U-shaped steel brackets of various configurations shown in ILLS. 2 and 2A, which were manufactured from 0.131 in. thick, 1-1/2 in. wide galvanized steel, were used as permanent fasteners about the cable tray insulation.

The conduit Kaowool insulation was permanently fastened with steel bands. Two types of steel bands were employed. A Type 316 stainless steel band (1/2 in. wide, 0.036 in. thick), and a coated steel band (3/4 in. wide, 0.031 in. thick) were used with their appropriate buckles and installed with the recommended banding tool.

The conduit Kaotemp insulation was fastened with No. 16 SWG (0.062 in. diameter) steel wire.

CONSTRUCTION OF RACEWAY SYSTEMS:

One cable tray and one conduit system were investigated in each test. Various types and number of cable lengths were installed into the cable trays, and one size and one type of cable was installed into the conduits as shown in ILL. 3 and as outlined in Table II.

All cables were cut into either 24 or 48 ft lengths. The 24 ft lengths were installed by routing the cable down the length of the tray, bending it at midlength and then routing it back to the end of the tray. The 48 ft cable lengths were installed similarly. However, these cables were routed down the length of the trays four times in lieu of two. Therefore, one 24 or 48 ft length of cable was considered as two or four 12 ft lengths of cable within the tray, and usually comprised one circuit as shown in Table II. One 24 ft length of cable was installed in a similar fashion into each conduit tested and comprised one circuit.

The cables were installed in two layers within the tray. The general pattern for cable installation is shown in ILL. 3A.

TABLE II - CABLE LOADING

Circuit No.	Test No. 1		Test No. 2		Test No. 3		Test No. 4	
	Cable Code	Number of 12 Ft Lengths						
1	C-19	2	C-19	2	C-19	2	C-19	4
2	C-22	2	C-23	4	C-23	4	C-24	2
3	C-23	4	C-24	2	C-24	2	C-24	2
4	C-24	2	C-24	2	C-24	2	C-24	2
5	C-24	2	C-24	2	C-24	2	C-24	2
6	C-24	2	C-25	2	C-25	2	C-25	2
7	C-25	2	C-24	2	C-25	2	C-25	2
8	C-25	2	C-26	2	C-26	2	C-26	2
9	C-26	2	C-27	2	C-27	2	C-27	2
10	C-27	2	C-33	2	C-33	2	C-33	2
11	C-33	2	C-33	2	C-33	2	C-33	2
12	C-33	2	C-33	2	C-33	2	C-33	2
13	C-33	2	C-33	2	C-33	2	C-33	2
14	C-33	2	M7-9	2	M7-9	2	M7-9	2
15	M7-9	2	M7-9	2	M7-9	2	M7-9	2
16	M7-9	2	M7-9	4	M7-9	4	M7-9	2
17+	M7-9	2	M7-9	2	M7-9	2	M7-9	2
18-20++	B1-9	2	B1-9	2	B1-9	2	B1-9	2

+ - Cable installed inside of conduit.

++ - One conductor cable. However, three circuits (two single phase and ground) were constructed by connection to single strands.

Each cable tray was wrapped with insulation as shown in ILLS. 5-8. The insulation was installed with overlaps and staggered joints. Initially, one piece of Kaowool approximately 18 in. wide by 78 in. long was cut and placed on top of the cables within the tray. Two pieces of Kaowool were then wrapped side by side around the tray forming one layer. The ends of each piece were overlapped and the common side between pieces butted. Adhesive tape was wrapped randomly around each piece to temporarily secure the insulation.

In Tests 1, 2 and 3, two pieces were then wrapped side by side around the tray to form a second insulation layer. The width of the Kaowool pieces was different than that of the first layer so as to provide an offset between the location of the butt joint in the first and second layers. The ends of each piece were overlapped with the overlap staggered between the first and second layers. Adhesive tape was then randomly wrapped about each piece to temporarily secure the insulation. Details of the insulation installation for Tests 1-3 are shown in ILLS. 5-7.

In Test 4, in lieu of installing a complete second layer of insulation, a 4 in. wide strip of insulation was placed over the first layer butt joint which was located at the midpoint of the tray. The ends of the strip were overlapped 6-1/4 in. and the piece temporarily secured with tape. Additionally, strips were installed outside the furnace chamber near the ends of the insulation. Brackets were installed over these 4 in. strips. Details of the insulation installation for Test 4 are shown in ILL. 8.

After the insulation wrapping for the tray was completed, brackets were fastened about the insulated trays. The locations of these brackets are shown in ILLS. 5-8. The brackets were fastened by tightening the bracket bolt and thereby clamping the insulation into place.

Kaowool insulation was installed in two layers about the conduit in Tests 1-3. Two pieces of Kaowool were wrapped side by side around the conduit forming one layer. The ends of each piece were angle cut and butted with each other or overlapped approximately 3 in. The common side between pieces was butted. Adhesive tape was wrapped randomly around each piece to temporarily secure the layer. Two pieces were then installed similarly forming a second layer. The width of the pieces differed from that of the first layer so as to provide an offset between the location of the butt joint in the first and second layers. The ends of each piece were angle cut and butted or overlapped with the joint or overlap staggered between the first and second layers. Adhesive tape was then used to temporarily fasten the outer layer.

Steel bands were then tightened about the insulation located as shown in ILLS. 5-7. The bands were installed with the banding tool recommended by the band manufacturer. The bands were tightened compressing the insulation.

In Test 4, Kaotemp insulation was installed about the conduit. Two 26-3/4 in. wide pieces of Kaotemp were installed with their common side butted at the midpoint of the conduit. The insulation was secured with steel wire ties twist tied and located as shown in ILL. 8.

LJP/KWH:plh

T E S T   R E C O R D

The four fire tests were conducted in accordance with the following test method and observed performance is described below.

## METHOD

One cable tray and one conduit system were inserted through the furnace chamber as shown in ILL. 9 for each test. The conduit was supported by pipe hangers located outside and approximately 2 in. away from the front and rear surface of the furnace. The cable tray was supported by the furnace walls and an independent stand outside of the furnace chamber. Location of the raceways within the furnace is shown in ILL. 9. The remaining furnace opening about the specimens was filled with Kaowool, the ends of the conduit stuffed with Kaowool, and space between the cables filled with fire brick dust.

Eight Type K thermocouples were installed in various locations as shown in ILLS. 10, 12, 14 and 16. One Type B thermocouple was used to monitor the furnace temperature and was located approximately 1 to 2 in. above the tray along the centerline of the furnace, 15 in. from the rear furnace wall.

The furnace was controlled by feedback from the furnace thermocouple. It was planned that the measured furnace temperature for each test be in accordance with the standard temperature-time curve as described in ASTM E119 "Fire Tests Of Building Construction Materials."

Power (220 v) was supplied to each cable circuit as shown in ILL. 4. One circuit breaker was installed for each circuit. Circuit integrity was monitored by visual observation of incandescent light bulbs. Two light bulbs were provided for each circuit as shown in ILLS. 4 and 9A. The lights were connected in parallel so as to provide one back-up bulb for each circuit in case of failure of the light bulb filament.

At the initiation of each test, all circuits were energized. Upon failure of a circuit (i.e., short circuit), the circuit breaker tripped and the light bulbs for that circuit were de-energized. Since there were no furnace windows, visual observation of the furnace fire and exposed surfaces of the specimens was not possible.

Throughout each test, temperature measurements and times at which failures of circuits (monitoring light board) occurred were recorded.

### RESULTS

Furnace Temperatures - The furnace temperature as measured by the one Type B thermocouple for each test are shown in ILLS. 11, 13, 15 and 17.

Temperatures - The temperatures within and on the cable tray, and within the conduit for each test are shown in ILLS. 11, 13, 15 and 17.

Circuit Failure - The times at which circuit failure occurred are presented for each test in Tables III-VI.

Post Test Observations - In general, the ceramic insulation appeared to have a brown char near each joint. The Okolon cable jacket material changed to white ash while the PVC cable jacket material decomposed exposing the copper sheath and leaving a black residue char. The general appearance of the insulation and cables after the test is shown in ILLS. 18 and 19.

LJP/KWH

S U M M A R Y

In consideration of the character of the investigation, the foregoing Report is to be construed as information only and should not be regarded as conveying any conclusion or recommendations on the part of Underwriters Laboratories Inc. regarding the acceptability of the construction or performance of the product for recognition by any code or standard or for any other purpose.

In general, small scale tests individually do not represent all factors associated with fire performance under actual field conditions. Accordingly, these test results may not be generally applicable. The suitability of this test method for predicting full scale performance presently has not been determined by the Laboratories.

Based upon time to first circuit failure, the protection systems of Tests 1, 3 and 4 provided greater than 30 min of fire resistance when subjected to a fire exposure as described herein.

Based upon time of circuit failures, the tray protection systems with two complete layers of insulation protection (except Test 2) provided 11 to 21 min more resistance against fire than the Test 4 tray protection system with only one complete insulation layer.

Since Test 2 differed from Test 3 only by the location of tray insulation fasteners, the fastening method employed in Test 3 provided 50 min more protection than the fastening method employed in Test 2.

Report by:

*Leon J. Przybyla*

LEON J. PRZYBYLA  
Project Engineer  
Fire Protection Department

Reviewed by:

*R. L. Parks / K. W. Howell*

R. L. PARKS  
Associate Managing Engineer  
Fire Protection Department

*K. W. Howell*

K. W. HOWELL  
Associate Managing Engineer  
Fire Protection Department

LJP/RLP/KWH:plh

TABLE III

Circuit Failure Test No. 1

<u>Circuit No.</u>	<u>Time of Failure, Min/Sec Into Test</u>
1	51:00
20	56:00
11	57:00
19	58:30
3	58:30
18	61:00
17	65:00
5	67:00
4	69:30
2	70:00
8	70:00
6	70:00
15	70:00
7	70:00
12	75:00
Test Terminated	77:00

TABLE IV  
Circuit Failure Test No. 2

<u>Circuit No.</u>	<u>Time of Failure, Min/Sec Into Test</u>
2	11:30
5	11:40
7	12:30
8	13:20
6	13:35
9	14:00
3	14:45
11	14:50
1	17:30
4	18:30
10	22:15
14	26:00
Test Terminated	30:00

TABLE V

Circuit Failure Test No. 3

<u>Circuit No.</u>	<u>Time of Failure, Min/Sec Into Test</u>
1	61:30
16	62:00
19	65:10
2	66:00
20	67:30
5	68:30
3	69:25
4	70:20
18	71:20
Test Terminated	73:00

TABLE VI

Circuit Failure Test No. 4


<u>Circuit No.</u>	<u>Time of Failure, Min/Sec Into Test</u>
1	40:00
20	46:00
19	46:30
17	48:18
9	50:38
15	52:00
16	53:00
2	53:17
18	54:09
6	57:30
4	58:07
3	58:30
14	59:32
Test Terminated	60:00

I L L U S T R A T I O N SILL.  
No.

Description


- 
- |    |  |
|----|--|
| 1  | Furnace drawing.                                       |
| 1A | Furnace photograph.                                    |
| 2  | Brackets.  |
| 3  | Cable installation.                                    |
| 3A | General circuit locations.                             |
| 4  | Circuit breaker, cable diagram.                        |
| 4A | Right board circuit diagram.                           |
| 5  | Insulation construction Test 1.                        |
| 6  | Insulation construction Test 2.                        |
| 6A | Insulation construction appearance Test 2.             |
| 7  | Insulation construction Test 3.                        |
| 7A | Conduit insulation construction appearance Test 3.     |
| 7B | Tray insulation construction appearance Test 3.        |
| 8  | Insulation construction Test 4.                        |
| 8A | Tray insulation construction appearance Test 4.        |
| 8B | Conduit insulation construction appearance Test 4.     |
| 9  | Installation into furnace.                             |
| 9A | Circuit light board.                                   |
| 10 | Cable tray and conduit thermocouple locations, Test 1. |
| 11 | Temperatures versus time, Test 1.                      |
| 12 | Cable tray and conduit thermocouple locations, Test 2. |
| 13 | Temperatures versus time, Test 2.                      |
| 14 | Cable tray and conduit thermocouple locations, Test 3. |
| 15 | Temperatures versus time, Test 3.                      |
| 16 | Cable tray and conduit thermocouple locations, Test 4. |
| 17 | Temperatures versus time, Test 4.                      |
| 18 | General appearance after test.                         |
| 19 | General appearance after test.                         |

FURNACE




BURNERS

FRONT



SIDE




TOP


\* Vary between 18" - 24"

BRACKETS


TEST 1



Test 2




TEST 3 & 4





All brackets formed from 1-1/2" wide, 0.130 in thick steel. Brackets tightened with 1/4" x 1" machine screws and 1/4" hex nut.

ILL.2  
R 8758



FURNACE  
FRONT VIEW C78-11388


CABLE INSTALLATION



C78-11387

R8758  
Ill. 3

GENERAL CIRCUIT LOCATIONS




CABLE TRAY CROSS SECTION

9	10	11	12	13	14	15	16	16	15	14	13	12	11	10	9
1	2	3	4	5	6	7	8	8	7	6	5	4	3	2	1

18, 19, 20


CORRESPONDING CIRCUIT NUMBER




CONDUIT CIRCUIT

220/115V 1ϕ

18" CABLE TRAY  
33% - 35% FILL



COLD WATER  
PIPE GND



220/115V DIST PNL  
2P 15A CKT BRKRS  
ITE GFI


TAI

TAI


TB2

SHEET #2


**CKT LIGHTS**




T01




T01



T02



T01



NEUTRAL BUS ON CKY PANEL



TRAY CKTS 1-20

CKT 17 CONDUIT  
CKT 18-20 1/2" W9  
CKT 21 SPARE

Dist Panel

INSULATION CONSTRUCTION

TEST 1




BUTT JOINT OF EACH PIECE ANGLE  
CUT TO PROVIDE AN OVERLAP



ILL. 5  
R 8758

INSULATION CONSTRUCTION

TEST 2




BRACKETS




STAINLESS STEEL BANDS

COATED STEEL BANDS


ENDS OVERLAPPED  
~ 3"



INSULATION CONSTRUCTION APPEARANCE  
TEST 2  
CONDUIT PROTECTION



CABLE TRAY PROTECTION






R8758  
Ill. 6A

C78-11386

INSULATION CONSTRUCTION



TEST 3



COATED STEEL  
BANDS

STAINLESS STEEL  
BANDS



CONDUIT INSULATION CONSTRUCTION APPEARANCE  
TEST 3



C78-11385

R8758  
Ill. 7A

TRAY INSULATION CONSTRUCTION APPEARANCE  
TEST 3






C78-11384


R8758  
Ill. 7B

INSULATION CONSTRUCTION


TEST 4





PIPE INSULATION  
JOINT



PIPE INSULATION  
JOINT





TRAY INSULATION CONSTRUCTION APPEARANCE  
TEST 4



C78-11383

R8758  
III. 8A


CONDUIT INSULATION CONSTRUCTION  
TEST 4



C78-11382

R8758  
I11. 8B


INSTALLATION INTO  
FURNACE



C78-11381

R8758  
I11. 9

CIRCUIT LIGHT BOARD




C78-11380


R8758  
I11. 9A

CABLE TRAY and CONDUIT THERMOCOUPLE LOCATIONS

TEST 1





ILL.10  
R 8758



III, 11  
R 8758


CABLE TRAY and CONDUIT THERMOCOUPLE LOCATION

TEST 2




7 on top of insulation  
8 in conduit 59 in from end

TEMPERATURE VERSUS TIME TEST 2




CABLE TRAY and CONDUIT THERMOCOUPLE LOCATION

TEST 3





7 on top of insulation  
8 in conduit 59 in. from end



ILL. 15  
R 8758


CABLE TRAY nad CONDUIT THERMOCOUPLE LOCATION

TEST 4





7 on top of insulation  
8 in conduit 59 in. from end.  
5 on cable tray back center of crest.

# TEMPERATURE VERSUS TIME TEST 4




GENERAL APPEARANCE AFTER TEST



R8758  
Ill. 18

C78-11379

GENERAL APPEARANCE AFTER TEST



C78-11378

R8758

Ill. 19