

International Aircraft Systems Fire Protection Working Group

*Liquid Burner Development for
Powerplant Fire Test*

Yi-Huan Kao, Michael Knadler, Samir Tambe
and

San-Mou Jeng

School of Aerospace Systems

University of Cincinnati

November 16-17, 2011

Project Objective:

- Develop the operating settings for NexGen burner for powerplant fire tests
 - NexGen burner should **simulate** previously FAA approved liquid burners
 - NexGen burner should be **robust and repeatable**

Approach:


- Sensitivity of NexGen burner setup on burner temperature and heat flux calibration (International Aircraft Systems Fire Protection Working Group, May 2010)
- **Fire test results from NexGen burner operated at the same heat flux and temperatures**
- Derive the NexGen burner settings *future work*
 - Comparison of fire test results from different burners (Park, NexGen and ISO)

NexGen Burner



Both fuel and air rate can be accurately metered and controlled



Uninsulated Cone
(Inconel 661)




Modified Turbulator
(Four 1"x3/4" tabs)



Conclusions from previous work (1)

Turbulator with four 1"x 3/4" tabs creates better and more stable air/fuel mixing and provides:


- Higher and more uniform flame temperatures
- More repeatable flames
- We recommend these tabs to be added to NexGen burner design






Conclusions from previous work (2)

Burner flame temperature and heat flux is very sensitive to the fuel flow rate, but not as sensitive to the air flow rate

Air Sensitivity





Fuel Sensitivity



Conclusions from previous work (3)


For the same flame, temperature indicated by smaller TCs was around 100 F higher




Current Study

- Fire tests using burner settings with the same measured temperature and heat flux
 - Different air flow rate
 - Different thermocouple size
- Test samples and methods
 - Small size Sample (4"x4"x1/4" AL6061) and Large size Sample (12"x12"x1/4" AL6061)
 - Back side TCs to monitor the temperature history and post-test inspection


Test Rig #1 and TC Locations for 4"x4" Sample




TC Location @ Rear Side




- ✓ Test Sample: 4"x4"
- ✓ Exposure Area: 3"x3"



Test Rig #2 and TC Locations for 12"x12" Sample



TC Location @ Rear Side



✓ Test Sample: 12"x12"


✓ Exposure Area: 11"x11"

Test Conditions and Calibration Data (Small Sample)


Small	Test Conditions			Calibration Data		Burnthrough Time
	Test #	Fuel (GPH)	Air (SCFM)	Temp. (F)	Heat Flux (BTU/ft ² -s)	min
Fuel Leaner Case ($\phi=0.74$)	#1	2.20	67.6	1936.1	9.2	-
	#2			1951.4	9.3	-
Baseline Case ($\phi=0.80$)	#3	2.25	64	1949.6	9.1	-
	#4			1923.8	9.0	-
Fuel Richer Case ($\phi=0.87$)	#5	2.25	58.6	1951.3	9.3	17
	#6			1921.1	9.0	17
*Ambient Temp.=80~90 F, w/o forced convection				1935±20	9.2±0.2	

All tests were terminated at 17 min

Test Conditions and Calibration Data




Test Results: Small Sample




Test Results: Small Sample (after 17mins)


$\Phi=0.74$ (undamaged)




$\Phi=0.74$




$\Phi=0.80$ (surface melted)



$\Phi=0.80$



$\Phi=0.87$ (burned though @ 17 min)



$\Phi=0.87$




Test Conditions and Calibration Data (Large Sample)

Large	Test Conditions			Calibration Data		Burnthrough Time
	Test #	Fuel (GPH)	Air (SCFM)	Temp. (F)	Heat Flux (BTU/ft ² -s)	Min
Fuel Leaner Case ($\phi=0.76$)	#1	2.25	67.6	1919.6	9.4	15
	#2			1919.8	9.4	-
Baseline Case ($\phi=0.82$)	#3	2.25	62.2	1919.8	9.5	11.5
	#4			1919.6	9.4	-
Fuel Richer Case ($\phi=0.88$)	#5	2.25	57.7	1937.3	9.5	10
	#6			1926.3	9.5	10
*Ambient Temp.=80~90 F, w/o forced convection				1930±15	9.4±0.1	


Tests 1, 3, 5, 6 conducted up to burn through
 Tests 2, 4 terminated at 10 min

Test Results: Large Sample



Test Results: Large Sample (after 10mins)


$\Phi=0.76$ (undamaged)



$\Phi=0.82$ (surface melted)



$\Phi=0.88$ (burned through)



Burnthrough

@ 15 mins

@ 11.5 mins

@ 10 mins

Test Conditions and Calibration Data (Diff. TCs)

Large	Test Conditions			Calibration Data		Burnthrough Time
	Test #	Fuel (GPH)	Air (SCFM)	Temp. (F)	Heat Flux (BTU/ft ² -s)	Min
Small TCs ($\phi=0.8$:baseline)	#1	2.14	60.4	1907.9	9.0	-
	#2			1918.8	9.0	-
Big TCs ($\phi=0.82$:baseline)	#3	2.25	62.2	1919.8	9.5	11.5
	#4			1919.6	9.4	-
*Ambient Temp.=80~90 F, w/o forced convection						

Thermocouple Dimension Information


	Bead (inch)	Wire (inch)
Big	0.033	0.020 (AWG 24)
Small	0.020	0.012 (AWG 28)

***AC 20-135:**

thermocouple wire: AWG 20~30 (0.0100~0.0253 inch)


K-Type, bare bead, ¼" inch exposed wire

Test Results – Different TCs




Test Results_Diff. TCs(after 10mins)

Big TCs, (surface melted)



Small TCs, (undamaged)



Burnthrough

Survive

@ 11.5 mins

until 15 mins

Conclusion

- Tests were conducted at flames with different air/fuel ratios but the same heat flux and temperature calibrations:
 - More damage was observed for the fuel richer test condition as compared to the fuel leaner condition.
- Small test samples had less damage as compared to the large test samples.
- Tests results are sensitive to TC sizes in calibration process:
 - The temperature measured by small TCs could reach target temperature at lesser fuel flow rate resulting in lower heat flux.
 - Test sample could survive longer under the flame calibrated by small TCs.

Recommendations

- Both air and fuel flow rates for a liquid burner should be precisely controlled and metered
- Current Fire Test guidelines do not require reporting the fuel and air flow rates. For future tests we recommend
 - Fuel and air flow rates to be documented
 - Guidelines should include precise air and fuel flow rate settings
- The range of recommended thermocouple size should be made narrower to limit the effect of different thermocouple sizes