

Updated Experimental Investigation of the NexGen Burner

Fire Test Center

University of Cincinnati, Cincinnati, OH, USA

October 29, 2014

John Hasselbeck, Samir Tambe, and San-Mou Jeng

Project Overview

- Project Objective:
 - Develop the operating settings of NexGen burner for Powerplant fire tests
- Previous Work
 - Old Configuration (Turbulator & Stator):
 - Effect of Burner setup and calibration TC size on burner
 - Sensitivity of Burner to air and fuel flow rates and temperature
 - Effect of burner orientation on burner performance
 - Comparison of fire test results between NexGen and Gas burners
 - New Configuration (FRH):
 - Fuel spray and temperature maps for different FRHs and fuel nozzles
- Current Approach
 - Sensitivity of Burner to changes in operating conditions
 - Temperature distribution
 - Burnthrough tests (2024 Al, 24" x 24" x 1/8")

Current Approach

- Baseline Test
 - Test conditions used by the FAA for comparison tests:
 - Air – Pressure 50 psig, Temperature $50^{\circ} \pm 10^{\circ}\text{F}$
 - Fuel – Pressure 100 ± 5 psig (2.5 GPH), Temperature $42^{\circ} \pm 10^{\circ}\text{F}$
- Effect of Fuel Flow Rate
 - change in flow rate: $\pm 10\%$
- Effect of Air Mass Flow Rate
 - change in mass flow rate: $\pm 10\%$
- Effect of Fuel Temperature
- Effect of Air Temperature
- Effect of Burner Cone Design



Baseline Test - Temperatures


- Air Flow Settings

- 50 psig (265 PPH), 50 °F


- Fuel Flow Settings

- 105 psi (2.46 GPH), 42 °F

Equivalence Ratio, $\Phi = 0.92$



Baseline






Baseline Repeat




Baseline Test - Burnthrough

- Very good burnthrough repeatability for Baseline test
 - In general, burnthrough repeatability is ± 30 sec




Effect of Fuel Flow Rate - Temperatures


Test Condition	Air			Fuel			ϕ	Calibration (1" height)		Burnthrough (min:sec)
	P (psig)	m (PPH)	T (°F)	P (psig)	flow (GPH)	T (°F)		Avg T (°F)	HF (BT/ft ² -s)	
-10% fuel	50	265	50	80	2.15	42	0.8	1714	10.8	6:05
Baseline				105	2.46		0.92	1829	9.05	4:05
+10% fuel				125	2.66		0.99	1894	10.95	2:37



80 psig (2.15 GPH)



105 psig (2.46 GPH)






123 psig (2.66 GPH)



Effect of Fuel Flow Rate - Burnthrough


- Burnthrough times decrease significantly as fuel flow rate increases
- **Recommendation:** Tighter tolerance on fuel pressure (flow rate)
 - $\pm 5\%$ of baseline flow rate

Fuel pressure psig	Calibration (1" height)		Burnthrough (min:sec)
	Avg T (°F)	HF (BT/ft ² -s)	
80	1714	10.8	6:05
105	1829	9.05	4:05
123	1894	10.95	2:37




Effect of Air Mass Flow Rate - Temperatures


Test Condition	Air			Fuel			ϕ	Calibration (1" height)		Burnthrough (min:sec)
	P (psig)	m (PPH)	T (°F)	P (psig)	flow (GPH)	T (°F)		Avg T (°F)	HF (BT/ft ² -s)	
-10% air	43	239	50	105	2.46	42	1.02	1924	9.69	2:08
Baseline	50	265					0.92	1829	9.05	4:05
+10% air	57	293					0.83	1932	9.49	4:30




43 psig (239 PPH)



50 psig (265 PPH)






57 psig (293 PPH)



Effect of Air Mass Flow Rate - Burnthrough

- Burnthrough times decrease significantly as air mass flow rate decreases
 - No significant impact on calibration data
- **Recommendation:** Specify tolerance on air mass flow rate
 - $\pm 5\%$ of baseline flow rate


Air flow PPH	Calibration (1" height)		Burnthrough (min:sec)
	Avg T (°F)	HF (BT/ft ² -s)	
239	1924	9.69	2:08
265	1829	9.05	4:05
293	1932	9.49	4:30




Effect of Fuel Temperature - Temperatures

Test Condition	Air			Fuel			ϕ	Calibration (1" height)		Burnthrough (min:sec)
	P (psig)	m (PPH)	T (°F)	P (psig)	flow (GPH)	T (°F)		Avg T (°F)	HF (BT/ft ² -s)	
Cold Fuel	50	265	50	105	2.46	30	0.92	1932	9.34	3:31
Baseline						42	0.92	1829	9.05	4:05
Warm Fuel						70	0.92	1916	8.4	3:09
Hot Fuel						90	0.92	1870	9.91	3:29


30 F





42 F - Baseline



70 F






90 F



Effect of Fuel Temperature - Burnthrough

- No significant effect of fuel temperature on calibration or burnthrough


Fuel Temp °F	Calibration (1" height)		Burnthrough (min:sec)
	Avg T (°F)	HF (BT/ft ² -s)	
30	1932	9.34	3:31
42	1829	9.05	4:05
70	1916	8.4	3:09
90	1870	9.91	3:29




Effect of Air Temperature - Temperatures

Test Condition	Air			Fuel			ϕ	Calibration (1" height)		Burnthrough (min:sec)
	P (psig)	m (PPH)	T (°F)	P (psig)	flow (GPH)	T (°F)		Avg T (°F)	HF (BT/ft ² -s)	
Cool Air	50	265	40	105	2.46	42	0.92	1945	10.06	3:31
Baseline	50		50					1829	9.05	4:05
Warm Air	52		80					1953	11.63	3:05
Hot Air	53		100					1878	10.25	3:11


40 F





50 F Baseline



80 F






100 F





Effect of Air Temperature - Burnthrough

- No significant effect of air temperature on calibration or burnthrough

Air Temp °F	Calibration (1" height)		Burnthrough (min:sec)
	Avg T (°F)	HF (BT/ft ² -s)	
40	1945	10.06	3:31
50	1829	9.05	4:05
80	1953	11.63	3:05
100	1878	10.25	3:11



Comparison of Burner Cones



UC Cone (left):
-Inconel
-1 Piece Assembly

FAA Cone (right):
-Stainless Steel
-2 Piece Assembly




-Thickness, cone length and exit geometry identical




Effect of Burner Cone - Temperatures


Test Condition	Air			Fuel			ϕ	Calibration (1" height)		Burnthrough (min:sec)
	P (psig)	m (PPH)	T (°F)	P (psig)	flow (GPH)	T (°F)		Avg T (°F)	HF (BT/ft ² -s)	
UC Cone	50	265	50	105	2.46	42	0.92	1829	9.05	4:05
FAA cone								1889	10.95	2:57



UC Cone






FAA Cone



Effect of Burner Cone - Burnthrough


- Burner cone design has an impact on the calibration and burnthrough times

Test Condition	Calibration (1" height)		Burnthrough (min:sec)
	Avg T (°F)	HF (BT/ft ² -s)	
UC Cone	1829	9.05	4:05
FAA cone	1889	10.95	2:57




Burnthrough Time Compared to Previous Round Robin

- Maintaining recommended operating conditions of NexGen burner within 5% of fuel and air flow rate will result in 3.6 ± 1 minute burnthrough
- Current test does not have the addition of bolt-drop, resulting in slightly longer burnthrough times



Round Robin Testing:



Current Testing:



Conclusions and Recommendations

● Conclusions

- Fuel and Air mass flow rates have significant impact on burnthrough times
- No significant effect of fuel and air temperatures, as long as mass flows are maintained constant
- Burner cone design impacts the burnthrough time
- Current burner temperature average < 2000 F, heat flux satisfies minimum requirements
- Burnthrough time with FAA recommended operating conditions is similar to Round Robin testing on current liquid burner

● Recommendations

- We recommend the following tolerances for burner operating conditions:
 - Fuel flow rate: $\pm 5\%$ of baseline flow ($\pm 10\%$ of baseline pressure setting)
 - Fuel temperature: ambient conditions acceptable
 - Air mass flow rate: $\pm 5\%$ of baseline flow rate
 - Air Temperature: ambient conditions acceptable as long as mass flow is constant