

U.S. Army Hand Held Extinguisher Environmentally Acceptable Replacement Agent Development

Dr. J. Douglas Mather – U.S. Army Contractor CGI Federal (Stanley Associates, Inc.)



- United States (U.S.) Army Program Executive Office (PEO) Aviation initiated agent and hardware replacement effort.
- The U.S. Army Aviation Ground Support Equipment (AGSE) Product Manager Office (PMO) was tasked with finding acceptable agent and hardware to replace Halon 1301 HHFE.
- Project was initiated July 2008 and testing continued through April 2013.
- Aberdeen Test Center (ATC) performed all agent testing, hardware development and Special Sodium Bicarbonate (SBC_S) processing optimization.





Initial Project Goals and Strategy Were To **Develop An Extinguisher With:**

- Form, Fit and Function equivalent to current Halon 1301 HHFE ("Drop In Replacement" no changes to mounting bracket, no allowance for a larger or heavier cylinder.)
- Firefighting performance equivalent to current Halon 1301 HHFE performance (Hardware and agent configurations underwent concurrent development.)
- New agent to be commercially available and environmentally and toxicologically acceptable.
- The project was initially tasked to optimize four commercial agents and compare their pan fire performance to that of the existing Halon 1301 extinguisher.





- HFC-227ea (FM-200), boiling point -16 °C (2.3 °F)
- HFC-236fa (FE-36), boiling point -1.4 °C (29 °F)
- Halotron-I (HCFC-123), boiling point 27 °C (81 °F)
- Novec 1230, boiling point 49 °C (120 °F)





Final Optimized Agent/Hardware JP-8 Pan-fire Performance Comparison

<u>Agent</u>	Largest Pan Fire size (SQ FT)/attempts	Number of Extinguishments for Largest <u>Pan Fire</u>	Average Discharge Time Fire Out <u>(sec.)</u>
HFC-227ea	10/8	6	4.5
HFC-236fa	10/7	6	2.4
Halotron-I	12.5/6	6	3.0

NOTE: These are the three agents that we were able to optimize





Final Optimized Agent/Hardware N-Heptane Pan-fire Performance Comparison

Agent	Largest Pan Fire size	Number of Extinguishments for Largest Pan Fire	Average Discharge Time Fire Out (sec.)
HFC-227ea	<u>5/2</u>	2	3.8
HFC-236fa	5/2	0	
Halotron-I	5/2	0	





- FAA AC 20-42D gives guidance for the fire-fighting effectiveness, selection and safe-use of hand fire extinguishers in airplanes and rotorcraft.
- Safe-use (*Wt./Vol.*) guidance for various air change times, assuming perfect mixing, is presented in appendix 4, paragraph 2 of AC 20-42D





FAA Draft Circular AC 20-42D - Agent Discharge Limit (OH-58D 1 Minute Agent Clearance)

Agent Discharge limit (Lbs.)







FAA Draft Circular AC 20-42D – Agent Discharge Limit, (OH-58D 6 Minute Agent Clearance)

Agent Discharge limit (Lbs.)







<u>Agent</u>	<u>Test Phase</u>	Largest Pan Fire <u>SQ FT/attempts</u>	# Extinguishments for Largest <u>Pan Fire</u>	Discharge Time Fire Out (sec.)
Halon 1301	Baseline	12.5/5	3	7.5
HFC- 227ea	Final	10/8	6	4.5

NOTE: Down-select to HFC-227ea was made at this juncture



Average



Optimized HFC-227ea and Baseline Halon 1301 n-Heptane Pan-Fire Performance

				Average
			Number of	Discharge
		Largest	Extinguishments	Time Fire
	Test	Pan Fire	for Largest	Out
<u>Agent</u>	<u>Phase</u>	SQ FT/attempts	Pan Fire	<u>(sec.)</u>
Halon				-
1301	Baseline	1.5/6	4	1
HFC-				
227ea	Final	5/2	2	3.8

NOTE: Down-select to HFC-227ea was made at this juncture





Options to Improve HFC-227ea Pan Fire Extinguishment Performance

- In Dec 2009, HFC-227ea w/ Special Sodium Bicarbonate (SBC_S) powder was added to determine if this blend could meet or exceed the performance of the Halon 1301 configuration.
- Preliminary tests of SBC_S powder in HFC-227ea were very successful leading to a need to expand the development effort. Initial agent testing included:
 - Pan fire trials of various HFC-227ea/SBC_s blends
 - Characterization of obscuration effects on discharge in crew areas
 - Ease of cleanup of agent residue post discharge

NOTE: Preliminary trials with standard SBC was performed in the late summer of 2009.





SBC_s Powder Suppliers - Initial Testing

Quickfire USA



Nanomaterials Company





~1 micron





Development of Optimal SBC_s Powder Continued and Expanded to:

- Minimize the SBC_S loading required to improve HFC-227ea pan fire performance to be equivalent with the Halon 1301 HHFE.
- Develop SBC_S that suspend to fill the entire HFC-227ea liquid column.
- Develop new or identify existing commercial sources of optimal SBC_s powders.
- Evaluate long term stability of HFC-227ea/SBC_s agent (accelerated aging studies based on extended temperature cycling).
- Develop a reliable SBC_S moisture content characterization method having a low water quantification limit and establish a specification for SBC_S moisture content.
- Obtain SBC_S physical characterization information for use in procurement (particle size, morphology & surface area).
- Assist agent HFC-227ea/SBC_S health hazard assessments





- Jet Milling of SBC_S: Initial process development testing and production performed by Sturtevant Inc. (Fluid Energy Corporation did limited process testing)
- Wet Milling of SBC_s: This is a potential method for producing very small SBC_s particles in suspension unfortunately equipment was not available for use in SBC_s powder development.
- Spray Drying of SBC_s dissolved in water: Early testing was performed at Buchi Instruments. SBC_s powders produced had excellent suspendability in HFC-227ea. Limited scale up testing occurred at GEA Process Engineering with promising results.
- Proprietary methods of SBC_S nano-particle production: SBC_S powder process development was performed by Nanomaterials Company yielding SBC_S powders whose blends with HFC-227ea demonstrated very effective fire suppression in pan fire tests.





HFC-227ea/SBC_s Pan-Fire Performance of Sturtevant, Inc. and Nanomaterials Company SBC_s powders

JP-8 fuel

<u>Agent</u>	Max Pan Fire (SQ FT)/attempts	Max Pan Fire (SQ FT)/ <u>Fire out</u>		Pa (an Fire / Succe Y or N)/g	Attempt ess grams			Average Discharge Time - Fire <u>Out (sec.)</u>
Halon 1301	12.5/5	12.5/3	Y	Ν	Ν	Y	Y	-	7.5
HFC-227ea	12.5/6	12.5/1	Ν	Y	Ν	Ν	Ν	Ν	4.5
HFC-227ea/SBC _s (Sturtevant)	12.5/4	12.5/3	Y/70	Y/35	Y/21	N/21	-	-	3.8
HFC-227ea/SBC _s (Nanomaterials)	12.5/2	12.5/1	Y/20	N/35*	-	-	-	-	3.2

* Test Compromised





Nozzle Developed for Halotron-I and HFC-227ea/SBC_S Blended Agents







Nanomaterials Company SBC_s Powder Field Emission Scanning Election Microscopy (FESEM)



~1 micron





Nanomaterials Company SBC_s Powder FESEM







Sturtevant, Inc. SBC_s Powder FESEM



~1 micron





SBC_S Suspendability in HFC-227ea



Samples prepared at ATC Fire Lab for observation of SBC suspension properties and stability. SBC mixed with HFC-227ea at 5% by weight and ultrasonicated at 40Khz (250 watts/gal.) for 5 minutes.





~36% SBC_s Weight Loss on Heating



∞€€€€₽₽₽₽₽₽



Post Accelerated Aging HFC-227ea/SBC_s Slurry Flow Check (Nanomaterials Company, SBC_s Sample Tube 14 Thermal Cycling)







- Post thermal cycling agent SBC_S suspension levels had decreased
- Following repeated inversion (shaking by hand) each tubes SBC_s levels recovered to near original levels
- HFC-227ea/SBC_s slurries showed no change in their flow characteristics
- No SBC_S clumping or caking was observed in any of the test samples.





Additional HFC-227ea/SBC_s Testing Performed and Agent Evaluations Supported

- SBC_s water content. A solvent extraction and gas chromatography analysis based water content analytical method was developed by Galbraith Laboratories under a contract with Aberdeen Test Center. The analytical method number is AP GLI-Army C101.
- An SBC_S surface area. A measurement method based on Proton Nuclear Magnetic Resonance (NMR) allowing characterization of SBC_S powders was developed.
- SBC_S particle imaging (morphology). FESEM methods for imaging SBC_s powders and characterizing particle morphology were developed.
- Toxicity Clearances were provided by the U.S. Army Institute of Public Health for SBC-1 (March 2012) and SBC-2 (May 2012).





- A Health Hazard Assessment Report (HHAR) for the SBC-1 and SBC-2 was provided by the U.S. Army Institute of Public Health; June 2012.
- DuPont Fluorochemicals Analytical Laboratory Wilmington, DE ۲ performed a materials compatibility evaluation. The ANSI/ASHRAE Standard 97 was used as a testing guide. The report conclusion: "for a highly critical application, further testing at more aggressive test conditions may be needed. However, from the test conditions prescribed herein, signs of significant deterioration were not evident."
- A report detailing the HFC-227ea/SBC_s agent development effort is being drafted. It is expected to be publicly available early 2014.
- MIL-DTL- 32412 titled "HFC-227ea Fire Extinguishing Agent Enhanced with Special Sodium Bicarbonate Powder (HFC-227ea/SBC_S)" was published. Class I and Class II SBC_S powders are defined within the specification. This document is accessible via the internet.





- Moisture Content Limits for SBC_S
- Caking and Lumping Check Method
- HFC-227ea/SBC_S Slurry Flow Check ullet
- SBC_S Suspendability in HFC-227ea
- Average Particle Aspect Ratio (width/length) Limits
- SBC_S Powder Surface Area Acceptable Range
- Particle Size Requirement (Longest Dimension) •
- SBC_s Concentrations in HFC-227ea in Weight %
- Color
- SBC_S Water Content (ppm) Range
- Surface Area Characterization Instrumentation and Method
- **FESEM Sample Preparation and Analysis Technique**





Program Leads and Key Contributors

Alivio Mangieri – AGSE PM Technical Branch

Timothy Helton – U.S. Army Aviation and Missile Command (AMCOM) G-4

Kevin Dowell and Leonard Lombardo – Aberdeen Proving Ground





Acknowledgements

Funding – PEO Aviation, Program Manager Aviation Systems, PM AGSE

Technical Management – Aviation Ground Support Engineering (AGSE)

Supporting Organizations

Aberdeen Test Center (ATC), Intermediate Fire Lab Tyndall AFB - Air Force Research Laboratory (AFRL) US Aberdeen Proving Ground, Army Institute of Public Health

Special Thanks – The support staff at the Intermediate Fire Lab, ATC

DuPont Company – contributed FM-200 and FE-36 agents and performed materials compatibility testing of HFC-227ea/SBC_S agent with HHFE hardware components

Quickfire USA – contributed powdered agent for crucial initial HFC227ea and SBC evaluations

3M Corporation – contributed Novec 1230

American Pacific Corporation - contributed Halotron-I





Questions

Any presentation related questions should be addressed to:

Mr. Tim Helton U.S. Army Aviation and Missile Command (AMCOM) G-4

E-mail: tim.helton@us.army.mil





Backup Slides





PEO Aviation Cradle to Grave Lethality!

ATC Pan Fire Test







OH-58D HFC-227ea/SBC_s Initial Testing of Visual Obscuration Photo at ~4.5 seconds from start of HHFE discharge



Aircraft Doors and Windows Closed During and Post Discharge

SBC_S supplied by Quickfire USA





OH-58D HFC-227ea/SBC_s Visual Obscuration Discharge Photo ~1 second after discharge completion



Aircraft Doors and Windows Closed During and Post Discharge

Total Discharge Time ~8.0 Seconds





24" High Pressure Glass Tube and Pipe Over-Pressure Sleeve (glass tubes manufactured by Andrews Glass Company)







PEO Aviation Cradle to Grave Lethality

Tubes Kept Vertical During and After Accelerated Aging Thermal Cycling







Lethalityi

Thermal Cycling Test Chamber







Accelerated Aging Sample Compositions

Pressure Tube	Sample Description	Sample type
IADEL #	Sample Description	Sample type
1	SBC-1/Dry 1	Control
2	SBC-1/Dry 2	Diurnal sample
3	SBC-1/Dry 3	Diurnal sample
4	SBC-1/AR 1	Control
5	SBC-1/AR 2	Diurnal sample
6	SBC-1/AR 3	Diurnal sample
7	SBC-1/300 1	Control
8	SBC-1/300 2	Diurnal sample
9	SBC-1/300 3	Diurnal sample
10	SBC-1/600 1	Control
11	SBC-1/600 2	Diurnal sample
12	SBC-1/600 3	Diurnal sample





Accelerated Aging Sample Compositions - continued

Pressure Tube Label #	Sample Description	Sample type
13	SBC-2/Dry 1	Control
14	SBC-2/Dry 2	Diurnal sample
15	SBC-2/Dry 3	Diurnal sample
16	SBC-2/AR 1	Control
17	SBC-2/AR 2	Diurnal sample
18	SBC-2/AR 3	Diurnal sample
19	SBC-2/300 1	Control
20	SBC-2/300 2	Diurnal sample
21	SBC-2/300 3	Diurnal sample
22	SBC-2/600 1	Control
23	SBC-2/600 2	Diurnal sample
24	SBC-2/600 3	Diurnal sample
25	SBC-2 Slurry As Rec CONTROL	Control
26	SBC-2 Slurry As Rec.	Diurnal sample
27	SBC-2 Slurry As Rec.	Diurnal sample
28	SBC-2 Slurry 0.3ml water	Diurnal sample
29	SBC-2 Slurry 0.1ml water	Diurnal sample





Accelerated Aging SBC-1 (Tube 01) and SBC-2 (Tube 13) **Control Samples**









Sample 1: AA4

The specific surface area is estimated to be $14.2m^2/g$. This is based on a T₂ value of 1064ms, a specific surface relaxivity, k_a of 0.0026g/m²/ms, a bulk fluid relaxation time of 1319ms and a volume ratio of 0.049.





Surface area by NMR relaxation time (testing performed by XiGo Nanotools, Inc.)

Sample	Average T2	Surface Area
	(ms)	(m-g ·)
AA4	1064	14.3
	(stddev: 14.5; cov: 1.4%)	
AA5	1141	10.9
	(stddev: 70.1; cov: 6.1%)	
AA15	1065	19.3
	(stddev: 21.6; cov: 2.0%)	
AA16	1081	19.9
	(stddev: 27.2; cov: 2.5%)	
AA17	1048	17.4
	(stddev: 4.5; cov: 0.4%)	
XO2	1119	39.5
	(stddev: 9.7; cov: 0.9%)	





Hardware used in agent development







Pressures (Cylinder and at Nozzle) During Discharge (Test 27)







Testing and Test Equipment







PEO Aviation Cradle to Grave Letholity/ Development testing included evaluation of operational temperature limits

Qualification Testing as per DTP (Fire testing, Ambient, High/Low Operation Temp)



Production representative HHFE @ 70 °F FM-200/SBC-2 Agent 12.5 S.F. JP-8-fueled Pan Fire 15 Feb 2012



Production representative HHFE @ 160 °F FM-200/SBC-2 Agent 12.5 S.F. JP-8-fueled Pan Fire 15 Feb 2012



Production representative HHFE @ -60 °F FM-200/SBC-2 Agent 5 S.F. JP-8-fueled Pan Fire 15 Feb 2012





SBC handling employed a dry box kept at < 1% RH using 3A molecular sieve







Buchi – B290 bench scale spray dryer test







Buchi - B90 bench scale spray dryer test







Buchi B90 Powder FESEM (Spray Drying of SBC Solution)







PEO Aviation Cradle to Grave Lethality!

Buchi B290 Powder FESEM (Spray Drying of SBC Solution)







Buchi B290 Powder FESEM (Spray Drying of SBC Solution)





PEO Aviation Cradle to Grave Lethality/ Buchi B290 and B90 spray dryer generated SBC samples suspended in HFC-227ea



Micronizer Jet Mill

Reproduced with permission of STURTEVANT, INC. Hanover, MA

SBC suspendability in HFC-227ea

Laser Illumination of HHFE Spray

