

Development of a Lab-Scale Test For Evaluating Decomposition Products of Burnthrough Compliant Insulation Systems



Tim Marker
FAA Technical Center

Fuselage Burnthrough Chronology

Full-scale test article built at FAATC in mid 1990's for evaluating performance of burnthrough-resistant thermal acoustic insulation materials.

Testing indicated burnthrough-resistant insulation provided a much more survivable cabin atmosphere when compared to current insulation materials.

FAA issued NPRM, 2003 Final Rule issued, 2009 compliance.

Although burnthrough resistant materials provide a benefit, the ingress of toxic gases resulting from decomposition of the insulation needs to be quantified.

2005 FAATC began development of a lab-scale test for evaluating toxic gas decomposition products that could be generated inside fuselage during a postcrash fire.

Development of Lab-Scale Test For Measuring Decomposition Products During a Postcrash Fire

It is anticipated that this test method could be used to evaluate the potential toxicity of insulation constructions and innovations meeting the new burnthrough test requirements, in order to ensure that an *adverse* condition will not result inside an intact fuselage when exposed to an external fuel fire, despite the high burnthrough performance associated with a particular system.

This test method could also be used to evaluate the toxic contribution of the basic fuselage structure, whenever a nonmetallic material is used as the primary component.

Methodology

Conduct lab-scale burnthrough test on 2 types of burnthrough resistant insulation, and 1 type of structural composite material (without insulation). Measured the build-up of toxic and flammable gases within an enclosure simulating a fuselage

complete

Conduct subsequent full-scale tests with identical insulation materials to establish realistic baseline data using FTIR.

complete


Determine concentration scaling factor between lab and full-scale tests in order to develop appropriate pass/fail criteria for lab-scale test.

complete

Produce Final Report and guidance on the acceptable level of decomposition products generated during lab-scale box test.

pending

Apparatus for Evaluating Toxic Gas Decomposition Products



Lab-Scale Apparatus for Evaluating Toxic Gas Decomposition Products


Burner configuration according to 25.856(b) Appendix F, Part VII.

Steel cube box simulates intact fuselage and serves as enclosure to collect emitted gases.

Fourier Transform Infrared (FTIR)/Total Hydrocarbon Gas analysis system used to collect and measure toxic and flammable gases yielded during tests.

Additional analyzers measured the concentration of carbon monoxide, carbon dioxide, oxygen, and total hydrocarbons (THC) as propane.

FTIR and THC Sampling System Used in Lab-Scale Testing




Gases Measured By FTIR

Toxic Gases	
$C_6H_5NH_2$	Aniline
C_6H_5OH	Phenol
C_6H_6	Benzene
CH_2CHCHO	Acrolein
CH_4	Methane
CO	Carbon Monoxide
CO_2	Carbon Dioxide
$COCl_2$	Phosgene
COF_2	Carbonyl Fluoride
COS	Carbonyl Sulfide
HBr	Hydrogen Bromide
HCL	Hydrogen Chloride
HCN	Hydrogen Cyanide
HF	Hydrofluoric Acid
NH_3	Ammonia
NO	Nitrogen Oxide
NO_2	Nitrogen Dioxide
SO_2	Sulfur Dioxide


Flammable Gases	
C_2H_2	Acetylene
C_2H_4	Ethylene
C_2H_6	Ethane
C_3H_8	Propane
$C_6H_5NH_2$	Aniline
C_6H_5OH	Phenol
C_6H_6	Benzene
CH_2CHCHO	Acrolein
CH_4	Methane
Other Gases	
CO_2	Carbon Dioxide
H_2O	Water
N_2O	Nitrous Oxide

Material Systems Tested in Lab-Scale Apparatus




PAN Insulation Test Using FTIR Analysis


051213 Box Test 5-- PAN/ Metalized PVF




PAN Insulation Test Using Gas Analyzers




FG/Ceramic Barrier Insulation Test Using FTIR Analysis



Comparison of Box Test Results at 5 Minutes



Comparison of Box Test Results at 5 Minutes



**Development of a Laboratory-Scale
Test for Evaluating the Decomposition
Products Generated Inside an Intact
Fuselage During a Simulated Postcrash
Fuel Fire**

Timothy R. Marker
Louise C. Speitel


April 2007

DOT/FAA/AR-TN07/15


This document is available to the public through the National Technical
Information Services (NTIS), Springfield, Virginia 22161



Full-Scale Test Article for Evaluating Decomposition Products of Burnthrough Compliant Insulation Systems and Non-Metallic Fuselage Structure




Full-Scale Test Article for Evaluating Decomposition Products of Burnthrough Compliant Insulation Systems and Non-Metallic Fuselage Structure




Full-Scale Test Article for Evaluating Decomposition Products of Burnthrough Compliant Insulation Systems and Non-Metallic Fuselage Structure



Full-Scale Test Article for Evaluating Decomposition Products of Burnthrough Compliant Insulation Systems and Non-Metallic Fuselage Structure



FTIR and THC Sampling System Used in Full-Scale Testing



Full-Scale Test Results PAN Insulation System

Full-Scale Test Results, PAN Insulation System



Full-Scale Test Results, PAN Insulation System

Pre-test



Full-Scale Test Results, PAN Insulation System

Post-test



Full-Scale Test Results, PAN Insulation System


Post-test



Full-Scale Results, PAN Insulation, Gas Analyzers

Carbon Monoxide Levels


PAN Insulation, already corrected



Full-Scale Results, PAN Insulation, Gas Analyzers


Carbon Dioxide Levels

PAN Insulation, already corrected




Full-Scale Results, PAN Insulation, FTIR


Full-Scale Test PAN Metallized PVF (10/25/2007)
Mid Station at 5' 6"



Full-Scale Results, PAN Insulation, FTIR



Full-Scale Results, PAN Insulation, Comparison



Full-Scale Test Results
Ceramic Barrier Insulation System
(Modified Configuration)

Full-Scale Test Results, Ceramic Barrier Insulation System II

Pre-test



Full-Scale Test Results, Ceramic Barrier Insulation System II



Full-Scale Test Results, Ceramic Barrier Insulation System II

Post-test



Full-Scale Test Results, Ceramic Barrier Insulation System II

Post-test



Full-Scale Test Results, Ceramic Barrier Insulation System II

Post-test



Full-Scale Test Results, Ceramic Barrier Insulation System II


Post-test



Full-Scale Results, Ceramic Barrier Insulation II, Gas Analyzer

Carbon Monoxide Levels


FG/Nextel 2nd test, already corrected for lag




Full-Scale Results, Ceramic Barrier Insulation II, Gas Analyzer

Carbon Dioxide Levels


FG/Nextel 2nd test, already corrected for lag



Full-Scale Results, Ceramic Barrier Insulation II, FTIR




Full-Scale Results, Ceramic Barrier Insulation II, Comparison



Full-Scale Test Results Structural Composite System

Full-Scale Test Results, Structural Composite System

Pre-test



Full-Scale Test Results, Structural Composite System




Full-Scale Test Results, Structural Composite System

Post-test



Full-Scale Test Results, Structural Composite System

Post-test



Full-Scale Test Results, Structural Composite System


Post-test



Full-Scale Results, Structural Composite, Gas Analyzer

Carbon Monoxide


Carbon/Epoxy, already corrected for lag




Full-Scale Results, Structural Composite, Gas Analyzer

Carbon Dioxide Levels


Carbon/Epoxy, already corrected for lag




Full-Scale Results, Structural Composite, FTIR




Full-Scale Results, Structural Composite, FTIR




Full-Scale Results, Structural Composite, Comparison




Full-Scale Results, Comparison of 3 Insulation Systems



Fractional Effective Dose Comparison Forward Station, 66" Height




Fractional Effective Dose Comparison Mid Station, 66" Height



What do we do with all this data?

How does data compare to small scale results?

Determination of Full Scale Test Article Volume



Forward Volume = Cabin Area x Fwd Length = $(10989.9/144) \times 68 = 5189.7$ cu ft


Mid Volume = Total Cabin Area x Mid Length = $(17203/144) \times 20 = 2389.4$ cu ft

Aft Volume = Cabin Area x Aft Length = $(10989.9/144) \times 22 = 1679$ cu ft

Total Volume = Forward Volume + Mid Volume + Aft Volume

Total Volume = $5189.7 + 2389.4 + 1679$

Total Volume = 9258.1 cu ft



Determination of Gas Concentration Scaling Factor

$$\text{Ratio of Volume}_{\text{Box}} \text{ to Burn Area}_{\text{Box}} = 60.33 \text{ ft}^3 / 9.25 \text{ ft}^2 = 6.52$$


$$\text{Ratio of Volume}_{\text{FSTest}} \text{ to Burn Area}_{\text{FSTest}} = 9258.1 \text{ ft}^3 / 64 \text{ ft}^2 = 144.7$$

$$\text{Ratio of Full Scale to Lab Scale} = 144.7 / 6.52 = \mathbf{22.2}$$


Full-Scale Test Article has 22.2 Times More Volume per Burn Area than Lab Scale Box

Theoretical Lab Scale Box Concentration is 22.2 Times Greater than Full Scale Concentration


Gas Concentration Scaling, PAN Insulation System



Gas Concentration Scaling, Ceramic Barrier Insulation System



Gas Concentration Scaling, Structural Composite System



Gas Concentration Scaling, Findings

Analysis only considers volumetric aspects

Analysis assumes perfect mixing

Analysis does not consider surface area effects

Not all of gases scale similarly (example: COS)

Primary intoxicants (CO, HCN) scaled similarly

Development of Decomposition Products Limits for Burnthrough Compliant Insulation Systems

Difficult to use volumetric scaling as basis for setting limits in lab-scale test.

Since full-scale tests did not result in adverse conditions inside fuselage,

Take maximum (peak) values obtained in box test for each gas,

Add reasonable safety factor,

Establish acceptable decomposition limits in box test

Development of Decomposition Products Limits for Burnthrough Compliant Insulation Systems

Example: HCN

During full-scale tests, HCN did not reach toxic levels for any of three materials

During lab-scale tests, HCN reached the following levels:

PAN material 470 ppm

FG/ceramic barrier 120 ppm

Composite skin 0 ppm

HCN acceptable limit would be set at 500 ppm in box test.

If a burnthrough compliant material produced greater than 500 ppm HCN during a box test, then a full-scale test would be necessary.

Fields 5 minutes test	Full-Scale Test Data							Allowable Exposure from Various References					FED Effect	Lab-Scale Data			Acceptable Lab-Scale Tox Limit= 5 Min Exp Limit x Scaling Factor (ppm)	Acceptable Lab-Scale Tox Limit (ppm)	FED Effect	Scaling Factor Mid Station at 5'6"			Gases to Measure FED > .02	Max Allowable Conc. (ppm) Max B Test Conc		
	PAN/Met PVF		FG/Ceramic Barrier/Met PVF (260 Sec)		Structural Composite		5 Minute Exposure				60 Minute Exposure	30 Minute Exposure		PAN/Met PVF	FG/Ceramic Barrier/Met PVF	Structural Composite				PAN/Met PVF	FG/Ceramic Barrier/Met PVF (260 Sec)	Structural Composite				
	Mid Station at 5'6"	Fwd Station at 5'6"	Mid Station at 5'6"	Fwd Station at 5'6"	Mid Station at 5'6"	Fwd Station at 5'6"	Incap Conc	LC50	Derived from 60 min ERPG3	Derived from 30 min IDLH	ERPG 3 (2007)	IDLH (1995)														
	Mid Station at 5'6"	Fwd Station at 5'6"	Mid Station at 5'6"	Fwd Station at 5'6"	Mid Station at 5'6"	Fwd Station at 5'6"	Incap Conc	LC50	Derived from 60 min ERPG3	Derived from 30 min IDLH	ERPG 3 (2007)	IDLH (1995)		FED Effect	PAN/Met PVF	FG/Ceramic Barrier/Met PVF				Structural Composite	Acceptable Lab-Scale Tox Limit (ppm)	Acceptable Lab-Scale Tox Limit (ppm)			FED Effect	PAN/Met PVF
H2	4.63	3.27	5.5	3.27	1.73	0.29	Not Avail			600	?	100	0.009	68.73	91.14	6.14	600 x 15.7 (IDLH)	9,420	0.010	C6H5NH2	14.8	16.6	3.5			
PH	7.02	4.59	9.57	5.01	9.4	4	Not Avail		2400	1500	200	250	0.004	52.22	38.95	9.78	2400 x 4.2 (ERPG)	10,080	0.005	C6H5OH	7.4	4.1	1.0			
	10.46	10.41	8.05	4.56	7.21	3.21	?	?	12,000	3000	1000	500	0.001	76.60	52.5	8.33	12,000 x 5.0 (ERPG)	60,000	0.001	C6H6	7.3	6.5	1.2			
CHCHO	0	0	0	0	0	0	10928	7783	18	12	1.5	2	0.000	55.50	146.04	0	7783 x 4 (LC50)	31,132	0.005	CH2CHCHO	#DIV/0!	#DIV/0!	ND			
	0	0	0	0	0	0	?	102 d	12	12	1	2	0.000	0.00	3.9	0	102 x 4 (LC50)	408	0.010	COCI2	ND	#DIV/0!	ND			
	0	0.21	0	0	0	0	?	?	300		25 (est)	?	0.001	0.00	0	0.43	300 x 4 (ERPG3)	1,200	0.000	COF2	ND	ND	#DIV/0!			
	0	0.61	0	0	0.53	0.34	500* (500 for 15min-brain damage)	(1000 for 15 minutes)	1200 (H2S)				0.001	38.66	0	0.84	500 x 4	2,000	0.019	COS	>40	ND	1.6	Yes	5	
	0	0	0	0	0	0	16830	15900	1800	180	150 (est)	30	0.000	0.00	0	0	15900 x 4 (LC50)	63,600	0.000	HBr	ND	ND	ND			
	0	0	0	0	0.49	0.29	16830	15900	1800	300	150	50	0.000	0.00	0	3.43	15900 x 4 (LC50)	63,600	0.000	HCl	ND	ND	7.0			
Peak)	16.4	10.75	0	0	0	0	176	560	300	300	25	50	0.093	467.00	111.74	0	176 x 20 (Incap)	3,520	0.133	HCN	28.5	#DIV/0!	ND	Yes		
	22.7	26.9					176	560	300	300	25	50	0.153	467.00	111.74	0	176 x 20 (Incap)	3,520	0.133	HCN	20.6		ND	Yes		
	0	0	0	0	0	0	7663	7227	600	180	50	30	0.000	14.46	19.3	0	7227 x 4 (LC50)	28,908	0.001	HF	#DIV/0!	#DIV/0!	ND			
	3.95	9.94	7.81	3.72	2.99	1	?	?			?	?		18.75	62.56	0		No Limit			N2O	4.7	8.0	ND		
	5.55	4.32	4.5	1.82	1.36	1	?	?	9000	1800	750	300	0.003	367.20	289.19	3.3	9000 x 65.3 (ERPG)	587,700	0.001	NH3	66.2	64.3	2.4			
	0	0	0	0	0	0	12850	4260	1800	600	150	100	0.000	0.00	0	0	4260 x 4 (LC50)	17,040	0.000	NO	ND	ND	ND			
	2.02	1.19	13.13	6.19	0	0	2570	852	360	120	30	20	0.007	0.00	0	0	852 x 4	3,408	0.000	NO2	ND	ND	ND			
	19.81	2.06	2.04	1.33	2.82	2.56	?	2115	180	600	15	100	0.009	246.57	0	31.17	2115 x 11.8	24,957	0.010	SO2	12.4	ND	11.1			
Peak)	55.4	65.5					?	2115	180	600	15	100	0.031	246.57	0	31.17	2115 x 4.5	9,518	0.026	SO2	4.5			Yes		
	190.9	104.8	99.18	44.49	7.7	4.2	6850	16600	6000	7200	500	1200	0.028	4645.76	2116.23	55.32	16600 x 17.6 (ERPG3)	292,160	0.016	CO	24.3	21.3	7.2	Yes	6	
	1367.6	730.3	2674.66	1608	42	30	88000						0.030	11506.60	12657	96.7	88,000 x 6.6	580,800	0.022	CO2	8.4	4.7	2.3	Yes c	17	
	1973.9	4885	3160.63	1684	627	276								10164.77	19430	1808.29	No Limit		N/A	H2O	5.1	6.1	2.9			
s ne n ion	97.9	72.2	68.17	55.21	22	20.8							0.005	629.71	903.5	22.0	21,000 x 6.9	144,900	0.006	THC as Propane Oxygen Depletion	6.4	13.3	1.0			
	3500	2100	6470	2920	150	0	136000							3000.00		1120	Remove				0.9		7.5			