HEAT RELEASE RATE Updates

Materials Working Forum Webinar #3 June, 2020 FAATC, NJ

Michael Burns, FAA Tech Center June, 2020



Ground Rules for Webinars and Zoom Meetings

Zoom Meeting Ground Rules:

- Everyone PLEASE go on mute
- Use raised hand feature (under participants button) to ask a question
- A panelist will read or call on participant to ask their question, as time permits
- Once question has been answered, click raised hand to "un-raise"



WEBINAR (0900 TO 1000):

- 1. HR2 Update FAATC (Mike Burns)
 - 15 minutes (0900 to 0915)
- 2. Observed Interactive Effects on OSU
 Apparatus Boeing (Theodoros Spanos)
 - 25 minutes (0915 to 0940)
- 3. HR2 TRL6 Update Boeing (Yaw Agyei)
 - 20 minutes (0940 to 1000)



Agenda

- BACKGROUND
- HR2 R&D Project Status
 - R&D Heater
 - > HR2 sonic choke research
 - Specifications
 - Installation
 - Calibration/Theoretical Data (Volume flow vs. Temp., Press.)
 - Task Group input



HR2 Update

BACKGROUND

- OSU Voltage Round Robin (March 2019 Boeing)
- Implemented globar voltage and current monitoring (April 2019)
- TRL 5 (Repeatability) May 2019
- NPRM released and on our FAA web site (July 2019; Chapter A4 Heat Release Rate Test)
- Conference Presentations (October 2019)
 - Detailed HR2 / OSU description of changes (M. Burns FAATC)



HR2 Update

BACKGROUND (Continued)

- Summary of Airflow Effects on Material Heat Release
 Results using OSU Calorimeter (T. Spanos Boeing)
- HR 2 Nominal Operating Parameters Range (Y. Agyei -Boeing)
- Current work (June 2020):
 - Investigation into MFC replacement with sonic choke –
 In progress (Mobile Nominal Operating Parameters)
 - TRL 6 (Reproducibility) In progress
 - R&D heater development In progress




HR2 R&D Heater

BACKGROUND

- Zone heater was developed to eliminate globars and to provide a more uniform and safer heater assembly
- First prototype used two heating zones
- FAA tests showed more efficient heating (less current) but not enough zonal adjustment
- Three zone unit manufactured with three different resistances




HR2 R&D Heater





HR2 R&D Heater



- The actual heater is complete with identical resistive heaters in all three zones
- Putting together an independent power supply unit with three separate AC/DC power supplies controlled by three Wallow controllers
- This will be shipped to the FAA
 Technical Center as soon as able to do so

- If inlet pressure and temperature to the sonic choke can be regulated <u>accurately</u>, the MFC can be replaced.
- Estimated uncertainty in mass flow rate of air approximately +/- 0.5% traceable to NIST
- FAATC acquired sonic choke / equipment (Fall 2019)
- Temperature control:
 - Thermal Transfer Products heat exchanger
 - Remcor Chiller/Heater
 - Type-K TC







- Pressure control:
- Pressure regulator
- ✓ ControlAir #7100-EAE
- ✓ ~ \$340 each






- High-accuracy pressure gauge
- ✓ PX309-050A10V
- ✓ ~ \$270 each







Testing & Certifications The following are included with supply of this Venturi. Flow Calibration -- X Hydrotest ---- Weld Dye Pen.---Weld Certs ---- X Radiograph 100% - 🗆 🗓 Cleaning Spec. -- X

Fox 3/4" Sonic Choke

Fox Part No. 625442

Fluid Media: Air at 34.7 psia, 72.5° F

Line Size: 3/4" Sch 40 pipe Material: 304 Stainless Steel Throat Dia: Approx. Dt = 0.208"

Design Flow Rate: Approx. 0.0269 lbs/sec of Air at 34.7 psia

Configuration: 3/4" male NPT ends

Calibration at CEESI:

Description: Air Flow Test at ambient temperature; "As Found" testing Choked Flow: Approximately (6-10) Data Points taken over an inlet


pressure range of about 24.7 to 44.7 psia

Accuracy: Estimated uncertainty in mass flowrate of air approx. ± 0.5%


traceable to NIST

CONTRACT NO.		Fox Venturi Products			
APPROVALS	DATE		Dover N.I.	LISΔ	www.foxvalve.com
DRAWN BY EAN	07/18/19	FOX	Dover, 140	UUA	www.loxvalve.com
APP. BY		3/4" Sonic Choke, Male NPT			
MATERIAL SS 304		For Fire Safety R&D For: DOT/FAA Atlantic City, NJ			
FINISH 32 RMS		SIZE REVIS	ION	DRAWING NO	
TOLERANCES UNLESS OTHERWISE SPECIFIED:		B 625442		42	
FRACTIONS: ± 1/8"		SCALE		SHEET# OF	





HR2 Sonic Choke Theoretical Data





- Cost: \$950
- Colorado Engineering Experiment Station Inc. (CEESI) Calibration: \$1,785
- Some questions for TG members:
 - O How/where to install (lower plenum, remotely etc.)?
 - O Distance from inlet fitting to lower plenum?
 - O Change lower plenum 1½" opening to accommodate a ¾" female NPT (choke/pressure regulator)?
 - Location of pressure transducer and TC as standard configuration?



- Temperature requirements will change from the lower plenum temperature TC 72.5 ± 2.5 °F to the sonic choke inlet temperature.
- Use of pressure or temperature sensors
 - Absolute pressure gauge required (0-50 psia)
 - Type K TC
- Frequency of calibration of pressure and temperature sensors



- Filtration requirements: Specific filter recommendation? Micron size?
- Calibration frequency (none required)? CEESI does not give a specific re-calibration interval.
 - "The sonic choke does not have any moving parts, and assuming there are no changes to internal dimensions or surface finish performance should be consistent."
- Cleaning requirements or standardized method?
- If desired, update placeholder document.



Questions?

