



OSU Calorimetry Test

Initial Results from 2016 Industry
OSU Round Robin

[Data Current up to 01 MAR 16]

Theodoros A. Spanos

Payloads Engineer, BCA

Bordeaux, France

16 MARCH 2016



Topics of Discussion:

- Motivation behind continued OSU study
- Quick summary of 2016 Industry Round Robin Data
- Discussion on the following parameters:
 - Airflow
 - Differential Pressures
 - Lab Conditions
 - Calibration Data
 - Heat Release Results
 - Correlations
- Next steps



Motivation Behind Study:

- **The Ohio State University Calorimetry (OSU) test used throughout the aircraft industry to determine the heat release of panels flown in the aircraft cabin interior**
 - Significant variation in round robin data acquired among industry labs has been noted

Goal: Establish an accurate baseline for the OSU tests industry-wide, by understanding and then controlling the possible variation due to airflow and other variables.

- **THANK YOU to all the industry-wide participants in the 2016 OSU RR and to Mike Burns [FAA] for compiling the data !**



Initial Results from 2016 Round Robin:

- News:

- As an industry, some critical OSU parameters are reporting the values below:

- **Total Airflow:**

- Average (μ): 86.41 CFM (Expecting 85 CFM)
- Standard Deviation (σ): 10.10
- Coefficient of Variation (% σ): 11.69%

- **Split Ratio:**

- Average (μ): 3.27 (Expecting 3.0)
- Standard Deviation (σ): 1.14
- Coefficient of Variation (% σ): 34.74%

- **Differential Pressure:**

- Average (μ): 106.68 in H2O (Expecting 107 in H2O)
- Standard Deviation (σ): 3.23
- Coefficient of Variation (% σ): 3.03%


- More News:

- As an industry, the variability of several key parameters is high
- More efforts in standardizing operating procedures & routine checks might be needed.
- Correlation between airflow, calibration constant, and HRR was not observed in this Round Robin data when reviewing industry data as a whole. Discussion to follow.




Topic: Airflow

Airflow



Split Ratio


| | Split Ratio |
|-------------|-------------|
| μ | 3.27 |
| σ | 1.14 |
| $\% \sigma$ | 34.74 |
| Nominal | 3.00 |






Topic: Differential Pressures

Upstream Pressure



Downstream/Vacuum Pressure




Orifice Meter Differential Pressure (107 INWC = 200 mmHg)






Topic: Laboratory Conditions

Lab Conditions



| | Lab Temp | Lab % RH | Lab Press |
|-------------|----------|----------|-----------|
| μ | 71.95 | 28.23 | 754.20 |
| σ | 2.88 | 12.13 | 14.32 |
| $\% \sigma$ | 4.01 | 42.98 | 1.90 |
| Nominal | 72-75 F | - | 760.00 |


Lab Atmospheric Pressure






Topic: Calibration Data

Center Heat Flux



Corner Heat Flux




Steps

| | 1 to 4 | 1 to 6 | 1 to 8 | 1 to 6 | 1 to 4 |
|-------------|--------|--------|--------|--------|--------|
| μ | 67.20 | 112.37 | 157.80 | 112.68 | 67.44 |
| σ | 1.78 | 3.23 | 5.32 | 3.00 | 1.63 |
| $\% \sigma$ | 2.65 | 2.87 | 3.37 | 2.66 | 2.41 |
| Nominal | - | - | - | - | - |




Baseline mV



■ No Flame (mv) ■ Flame (mv)

| | No Flame mV | Flame mV | Δ mV | Cal Factor |
|------------|-------------|----------|-------------|------------|
| μ | 21.41 | 26.64 | 5.23 | 11.19 |
| σ | 1.52 | 1.75 | 1.05 | 1.21 |
| % σ | 7.10 | 6.58 | 20.09 | 10.82 |
| Nominal | - | - | - | - |


Calibration Factor






Topic: Heat Release Results

Peak Heat [Blank Test Run]



| | PHR |
|-------------|-------|
| μ | 9.63 |
| σ | 3.88 |
| $\% \sigma$ | 40.34 |
| Nominal | 0 ? |


Total Heat Release [Blank Test Run]



| | 2-min THR | 5-min THR |
|-------------|-----------|-----------|
| μ | 5.47 | 22.02 |
| σ | 4.63 | 15.12 |
| $\% \sigma$ | 84.65 | 68.65 |
| Nominal | 0 ? | 0 ? |


■ 2-min THR ■ 5-min THR

Peak Heat [Schneller Panel]



| | PHR |
|-------------|-------|
| μ | 50.68 |
| σ | 5.14 |
| $\% \sigma$ | 10.14 |
| Nominal | - |

Total Heat Release [Schneller Panel]



| | 2-min THR | 5-min THR |
|-------------|-----------|-----------|
| μ | 38.60 | 86.60 |
| σ | 5.67 | 15.57 |
| $\% \sigma$ | 14.68 | 17.98 |
| Nominal | - | - |

■ 2 Min THR ■ 5 Min THR



Topic: Correlations

CORRELATION TABLE: An attempt at correlating the various parameters was made using the 'CORREL' function in Excel. Anything greater than 80% correlation is highlighted below. This data is inclusive of all laboratories reporting up to 01 MAR 16

| | Bypass CFM | Total CFM | Chamber SCFM | Bypass SCFM | Total SCFM | Min | Max | Delta | Bypass % | Chamber % | Ratio (3:1) | Airflow Temp | Airflow % RH | Interspace Area | Lower Plenum | Press Ratio | Upstream Pressure | Downstream Pressure | Differential Pressure | Lab Temp | Lab % RH | Lab Press | WTM Water Temp | WTM WVP | Center HF | Top Left | Top Right | Low Right | Low Left | Cal Factor | CF Ratio | Kb (STP correction) | | | | |
|-----------------------|------------|-----------|--------------|-------------|------------|------|------|-------|----------|-----------|-------------|--------------|--------------|-----------------|--------------|-------------|-------------------|---------------------|-----------------------|----------|----------|-----------|----------------|---------|-----------|----------|-----------|-----------|----------|------------|----------|---------------------|-------|-------|-------|------|
| Chamber CFM | 0.11 | 0.57 | 1.00 | 0.16 | 0.64 | 0.57 | 0.56 | 0.06 | -0.85 | 0.85 | -0.84 | 0.00 | 0.03 | 0.22 | 0.21 | 0.19 | 0.18 | 0.19 | 0.00 | 0.04 | 0.06 | 0.29 | -0.34 | -0.20 | -0.20 | 0.01 | 0.01 | 0.00 | -0.04 | 0.36 | 0.30 | 0.30 | | | | |
| Bypass CFM | | 0.88 | 0.05 | 0.99 | 0.83 | 0.88 | 0.88 | 0.33 | 0.41 | -0.41 | 0.29 | 0.09 | -0.47 | 0.30 | 0.10 | 0.26 | -0.09 | -0.16 | 0.13 | -0.03 | -0.22 | -0.60 | -0.01 | -0.03 | 0.09 | 0.18 | 0.04 | -0.39 | -0.14 | -0.42 | -0.32 | -0.71 | | | | |
| Total CFM | | | 0.52 | 0.90 | 0.99 | 1.00 | 1.00 | 0.30 | -0.06 | 0.06 | -0.16 | 0.08 | -0.38 | 0.36 | 0.18 | 0.31 | 0.01 | -0.04 | 0.11 | -0.01 | -0.15 | -0.36 | -0.16 | -0.12 | -0.02 | 0.16 | 0.04 | -0.33 | -0.14 | -0.18 | -0.13 | -0.46 | | | | |
| Chamber SCFM | | | | 0.11 | 0.60 | 0.52 | 0.51 | 0.05 | -0.88 | 0.88 | -0.86 | -0.03 | 0.05 | 0.19 | 0.20 | 0.15 | 0.20 | 0.22 | -0.01 | 0.04 | 0.09 | 0.37 | -0.33 | -0.18 | -0.18 | -0.02 | 0.00 | 0.03 | -0.05 | 0.39 | 0.31 | 0.37 | | | | |
| Bypass SCFM | | | | | 0.86 | 0.89 | 0.90 | 0.34 | 0.36 | -0.36 | 0.22 | 0.04 | -0.55 | 0.30 | 0.11 | 0.27 | -0.06 | -0.14 | 0.15 | -0.04 | -0.18 | -0.51 | 0.00 | 0.00 | 0.10 | 0.14 | 0.05 | -0.42 | -0.18 | -0.39 | -0.31 | -0.65 | | | | |
| Total SCFM | | | | | | 0.98 | 0.99 | 0.30 | -0.16 | 0.16 | -0.26 | 0.01 | -0.35 | 0.32 | 0.19 | 0.28 | 0.04 | 0.00 | 0.09 | 0.00 | -0.09 | -0.21 | -0.16 | -0.08 | 0.00 | 0.11 | 0.04 | -0.30 | -0.16 | -0.13 | -0.09 | -0.35 | | | | |
| Min | | | | | | | 1.00 | 0.26 | -0.07 | 0.07 | -0.17 | 0.08 | -0.37 | 0.36 | 0.19 | 0.29 | 0.02 | -0.03 | 0.10 | -0.02 | -0.14 | -0.36 | -0.17 | -0.13 | -0.03 | 0.16 | 0.05 | -0.32 | -0.14 | -0.18 | -0.13 | -0.45 | | | | |
| Max | | | | | | | | 0.33 | -0.06 | 0.06 | -0.16 | 0.08 | -0.38 | 0.36 | 0.17 | 0.32 | 0.00 | -0.05 | 0.11 | 0.01 | -0.16 | -0.36 | -0.17 | -0.12 | -0.01 | 0.16 | 0.03 | -0.34 | -0.13 | -0.18 | -0.13 | -0.46 | | | | |
| Delta | | | | | | | | | 0.12 | -0.12 | 0.08 | -0.01 | -0.27 | 0.10 | -0.26 | 0.46 | -0.24 | -0.35 | 0.19 | 0.30 | -0.34 | -0.11 | 0.01 | 0.07 | 0.25 | 0.06 | -0.23 | -0.29 | 0.17 | -0.04 | 0.03 | -0.33 | | | | |
| Bypass % | | | | | | | | | | -1.00 | 0.93 | 0.07 | -0.25 | -0.04 | -0.16 | -0.01 | -0.21 | -0.27 | 0.09 | -0.06 | -0.19 | -0.60 | 0.30 | 0.15 | 0.23 | 0.07 | 0.00 | -0.25 | -0.07 | -0.54 | -0.43 | -0.64 | | | | |
| Chamber % | | | | | | | | | | | -0.93 | -0.07 | 0.25 | 0.04 | 0.16 | 0.01 | 0.21 | 0.27 | -0.09 | 0.06 | 0.19 | 0.60 | -0.30 | -0.15 | -0.23 | -0.07 | 0.00 | 0.25 | 0.07 | 0.54 | 0.43 | 0.64 | | | | |
| Ratio (3:1) | | | | | | | | | | | | 0.07 | -0.24 | -0.10 | -0.22 | -0.09 | -0.16 | -0.21 | 0.09 | -0.11 | -0.19 | -0.61 | 0.32 | 0.08 | 0.31 | -0.07 | -0.13 | -0.27 | -0.15 | -0.42 | -0.33 | -0.53 | | | | |
| Airflow Temp | | | | | | | | | | | | | 0.06 | 0.13 | -0.24 | 0.36 | -0.09 | -0.02 | -0.15 | 0.32 | -0.22 | -0.23 | 0.10 | -0.02 | -0.30 | 0.10 | -0.06 | 0.22 | 0.30 | -0.15 | -0.10 | -0.14 | | | | |
| Airflow % RH | | | | | | | | | | | | | | -0.43 | -0.29 | -0.22 | -0.04 | 0.21 | -0.50 | 0.10 | 0.37 | 0.26 | -0.34 | -0.27 | -0.20 | -0.14 | 0.03 | 0.28 | -0.08 | 0.56 | 0.52 | 0.53 | | | | |
| Interspace Area | | | | | | | | | | | | | | | 0.69 | 0.64 | 0.31 | 0.20 | 0.25 | -0.06 | -0.18 | -0.34 | 0.13 | 0.10 | 0.07 | -0.11 | -0.50 | -0.07 | 0.09 | -0.28 | -0.26 | -0.23 | | | | |
| Lower Plenum | | | | | | | | | | | | | | | | -0.09 | 0.49 | 0.47 | 0.08 | -0.17 | -0.11 | -0.03 | 0.16 | 0.23 | -0.04 | 0.10 | -0.06 | -0.09 | 0.04 | -0.17 | -0.18 | -0.16 | | | | |
| Press Ratio | | | | | | | | | | | | | | | | | -0.12 | -0.23 | 0.20 | 0.19 | -0.08 | -0.21 | -0.02 | -0.02 | 0.08 | -0.25 | -0.55 | 0.01 | 0.10 | -0.12 | -0.08 | 0.01 | | | | |
| Upstream Pressure | | | | | | | | | | | | | | | | | | 0.88 | 0.33 | -0.29 | 0.13 | 0.16 | 0.33 | 0.23 | -0.04 | -0.48 | -0.20 | -0.13 | -0.32 | 0.11 | 0.02 | 0.18 | | | | |
| Downstream Pressure | | | | | | | | | | | | | | | | | | | | -0.16 | -0.20 | 0.14 | 0.24 | 0.26 | 0.19 | -0.13 | -0.39 | -0.12 | 0.09 | -0.24 | 0.21 | 0.12 | 0.23 | | | |
| Differential Pressure | | | | | | | | | | | | | | | | | | | | | -0.21 | 0.00 | -0.14 | 0.16 | 0.09 | 0.17 | -0.21 | -0.16 | -0.42 | -0.18 | -0.19 | -0.19 | -0.08 | | | |
| Lab Temp | | | | | | | | | | | | | | | | | | | | | | -0.45 | 0.08 | 0.48 | 0.58 | -0.42 | 0.45 | 0.14 | 0.25 | 0.62 | -0.12 | -0.06 | -0.05 | | | |
| Lab % RH | | | | | | | | | | | | | | | | | | | | | | | 0.38 | -0.36 | -0.33 | 0.25 | -0.56 | -0.18 | 0.10 | -0.50 | 0.31 | 0.24 | 0.38 | | | |
| Lab Press | | | | | | | | | | | | | | | | | | | | | | | | 0.05 | 0.26 | 0.00 | -0.26 | -0.02 | 0.33 | 0.03 | 0.39 | 0.27 | 0.75 | | | |
| WTM Water Temp | | | | | | | | | | | | | | | | | | | | | | | | | 0.92 | -0.15 | -0.04 | 0.04 | -0.03 | 0.15 | -0.38 | -0.37 | -0.12 | | | |
| WTM WVP | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.18 | 0.07 | 0.11 | 0.03 | 0.26 | -0.35 | -0.34 | -0.04 | | |
| Center HF | | | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.34 | -0.32 | -0.27 | -0.52 | -0.23 | -0.29 | -0.05 | |
| Top Left | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.64 | 0.15 | 0.62 | -0.33 | -0.25 | -0.41 | |
| Top Right | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.03 | 0.07 | -0.16 | -0.13 | -0.17 | |
| Low Right | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.53 | -0.19 | -0.25 | 0.20 | |
| Low Left | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.22 | -0.18 | -0.16 | |
| Cal Factor | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.98 | 0.58 | |
| CF Ratio | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.46 | |
| Kb (STP correction) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.46 |

Correlation Exists Between:

- Chamber Airflow & Bypass
- Total Airflow & Bypass

CORRELATION TABLE Continued

Unfortunate Note: Correlation between airflow and HRR has not been observed at this time.

| | 1-4 HRR | 1-6 HRR | 1-8 HRR | 1-6 HRR | 1-4 HRR | No Flame | Flame | mV Delta | PHR | PHR CV | PHR mV Rise | TTP | TTP CV | Rate of Rise | Rate of Fall | 2 Min THR | 2 Min THR CV | PHR/THR Ratio | 5 Min THR | 5 Min THR CV | THR Delta | Ending Avg HRR | Ending Avg HRR CV | PHR | PHR mV Rise | TTP | 2 Min THR | PHR/THR Ratio | 5 Min THR | THR Delta |
|-----------------------|---------|---------|---------|---------|---------|----------|-------|----------|-------|--------|-------------|-------|--------|--------------|--------------|-----------|--------------|---------------|-----------|--------------|-----------|----------------|-------------------|-------|-------------|-------|-----------|---------------|-----------|-----------|
| Chamber CFM | 0.04 | 0.20 | 0.50 | 0.32 | 0.07 | 0.25 | 0.17 | -0.08 | 0.03 | -0.07 | -0.28 | -0.29 | 0.15 | 0.28 | -0.07 | -0.09 | -0.07 | 0.04 | -0.10 | -0.12 | -0.11 | -0.11 | -0.13 | -0.10 | -0.19 | -0.29 | -0.08 | 0.25 | -0.01 | 0.02 |
| Bypass CFM | -0.13 | -0.45 | -0.39 | -0.38 | -0.02 | 0.34 | 0.09 | -0.34 | -0.08 | -0.24 | 0.27 | -0.20 | -0.18 | 0.21 | -0.04 | -0.24 | -0.29 | 0.24 | -0.34 | -0.19 | -0.39 | -0.39 | -0.10 | -0.13 | -0.05 | 0.26 | -0.21 | -0.15 | -0.18 | -0.17 |
| Total CFM | -0.09 | -0.28 | -0.10 | -0.10 | -0.02 | 0.34 | 0.09 | -0.32 | -0.05 | -0.24 | 0.10 | -0.30 | -0.08 | 0.30 | -0.07 | -0.24 | -0.27 | 0.22 | -0.33 | -0.22 | -0.37 | -0.37 | -0.14 | -0.15 | -0.13 | 0.09 | -0.21 | -0.02 | -0.16 | -0.13 |
| Chamber SCFM | 0.07 | 0.26 | 0.54 | 0.37 | 0.09 | 0.22 | 0.15 | -0.07 | 0.03 | -0.07 | -0.30 | -0.28 | 0.14 | 0.28 | -0.07 | -0.09 | -0.06 | 0.04 | -0.10 | -0.10 | -0.11 | -0.11 | -0.11 | -0.09 | -0.19 | -0.30 | -0.07 | 0.25 | 0.00 | 0.03 |
| Bypass SCFM | -0.08 | -0.38 | -0.32 | -0.32 | -0.02 | 0.31 | 0.05 | -0.36 | -0.07 | -0.27 | 0.25 | -0.21 | -0.18 | 0.22 | -0.03 | -0.24 | -0.28 | 0.24 | -0.35 | -0.18 | -0.41 | -0.41 | -0.08 | -0.12 | -0.05 | 0.24 | -0.21 | -0.14 | -0.16 | -0.14 |
| Total SCFM | -0.03 | -0.18 | 0.01 | -0.07 | -0.07 | 0.36 | 0.12 | -0.33 | -0.05 | -0.25 | 0.05 | -0.32 | -0.09 | 0.32 | -0.07 | -0.24 | -0.26 | 0.21 | -0.34 | -0.20 | -0.39 | -0.39 | -0.12 | -0.14 | -0.13 | 0.06 | -0.21 | 0.00 | -0.14 | -0.10 |
| Min | -0.10 | -0.27 | -0.09 | -0.17 | -0.01 | 0.41 | 0.17 | -0.31 | -0.06 | -0.22 | 0.09 | -0.29 | -0.06 | 0.29 | -0.07 | -0.25 | -0.27 | 0.22 | -0.33 | -0.21 | -0.37 | -0.37 | -0.14 | -0.16 | -0.14 | 0.09 | -0.21 | -0.01 | -0.16 | -0.13 |
| Max | -0.08 | -0.28 | -0.10 | -0.17 | -0.02 | 0.40 | 0.15 | -0.33 | -0.04 | -0.25 | 0.10 | -0.29 | -0.09 | 0.31 | -0.06 | -0.23 | -0.27 | 0.22 | -0.33 | -0.21 | -0.37 | -0.37 | -0.14 | -0.15 | -0.12 | 0.09 | -0.21 | -0.03 | -0.16 | -0.13 |
| Delta | 0.20 | -0.14 | -0.22 | -0.11 | 0.22 | -0.02 | -0.25 | -0.39 | 0.26 | -0.47 | 0.25 | -0.13 | -0.32 | 0.25 | 0.10 | 0.11 | -0.18 | 0.09 | 0.00 | -0.07 | -0.06 | -0.05 | -0.01 | 0.18 | 0.20 | 0.11 | -0.08 | -0.25 | -0.01 | 0.03 |
| Bypass % | -0.08 | -0.40 | -0.64 | -0.46 | -0.05 | -0.08 | -0.13 | -0.11 | -0.06 | -0.03 | 0.39 | 0.20 | -0.22 | -0.17 | 0.06 | -0.02 | -0.05 | 0.08 | -0.06 | 0.03 | -0.08 | -0.08 | 0.08 | 0.04 | 0.17 | 0.37 | -0.02 | -0.31 | -0.08 | -0.10 |
| Chamber % | 0.08 | 0.40 | 0.64 | 0.46 | 0.05 | 0.08 | 0.13 | 0.11 | 0.06 | 0.03 | -0.39 | -0.20 | 0.22 | 0.17 | -0.06 | 0.02 | 0.05 | -0.08 | 0.06 | -0.03 | 0.08 | 0.08 | -0.08 | -0.04 | -0.17 | -0.37 | 0.02 | 0.31 | 0.08 | 0.00 |
| Ratio (3:1) | -0.07 | -0.38 | -0.56 | -0.44 | -0.04 | 0.34 | 0.12 | -0.35 | -0.09 | -0.07 | 0.27 | 0.16 | -0.22 | -0.06 | 0.05 | -0.12 | -0.03 | 0.20 | -0.13 | 0.06 | -0.13 | -0.13 | 0.10 | 0.01 | 0.11 | 0.38 | -0.08 | -0.37 | -0.15 | -0.18 |
| Airflow Temp | -0.55 | -0.34 | -0.12 | -0.26 | -0.41 | 0.42 | 0.38 | 0.02 | -0.11 | 0.06 | 0.04 | -0.10 | -0.03 | 0.09 | -0.09 | -0.13 | 0.15 | 0.04 | -0.11 | 0.02 | -0.10 | -0.10 | -0.04 | -0.36 | -0.32 | 0.01 | -0.44 | -0.44 | -0.41 | -0.39 |
| Airflow % RH | 0.01 | 0.33 | 0.39 | 0.35 | 0.00 | -0.11 | -0.07 | 0.05 | 0.33 | 0.19 | -0.20 | 0.11 | 0.21 | 0.12 | 0.11 | 0.42 | 0.10 | -0.21 | 0.46 | 0.01 | 0.47 | 0.46 | -0.05 | 0.33 | 0.22 | 0.06 | 0.32 | 0.18 | 0.39 | 0.41 |
| Interspace Area | -0.03 | -0.27 | 0.00 | -0.25 | 0.01 | 0.33 | 0.37 | 0.14 | 0.25 | -0.17 | 0.43 | -0.15 | -0.11 | 0.04 | 0.17 | -0.06 | -0.06 | 0.29 | -0.09 | 0.00 | -0.10 | -0.10 | 0.01 | -0.11 | -0.07 | 0.32 | -0.17 | -0.06 | -0.13 | -0.11 |
| Lower Plenum | -0.13 | -0.16 | 0.08 | -0.21 | -0.10 | -0.08 | 0.10 | 0.28 | 0.12 | 0.09 | 0.22 | -0.09 | -0.09 | -0.28 | 0.03 | 0.13 | -0.31 | -0.09 | 0.11 | -0.29 | 0.09 | 0.10 | -0.28 | 0.16 | 0.19 | 0.21 | 0.30 | 0.47 | 0.29 | 0.27 |
| Press Ratio | 0.16 | -0.11 | 0.00 | -0.04 | 0.21 | 0.47 | 0.31 | -0.19 | 0.31 | -0.41 | 0.36 | -0.09 | 0.00 | 0.32 | 0.23 | -0.10 | 0.19 | 0.40 | -0.13 | 0.23 | -0.14 | -0.14 | 0.23 | -0.23 | -0.24 | 0.06 | -0.47 | -0.50 | -0.37 | -0.32 |
| Upstream Pressure | -0.02 | 0.44 | 0.56 | 0.41 | -0.10 | -0.03 | 0.16 | 0.31 | 0.11 | 0.38 | -0.01 | -0.17 | -0.09 | 0.00 | -0.01 | 0.09 | 0.18 | -0.07 | 0.02 | 0.26 | -0.02 | -0.01 | 0.27 | 0.14 | 0.19 | 0.13 | 0.15 | 0.18 | 0.13 | 0.12 |
| Downstream Pressure | -0.19 | 0.40 | 0.57 | 0.35 | -0.25 | -0.10 | 0.15 | 0.40 | 0.20 | 0.30 | -0.01 | -0.20 | -0.21 | 0.07 | 0.05 | 0.14 | -0.05 | -0.02 | 0.09 | 0.00 | 0.06 | 0.06 | 0.02 | 0.15 | 0.16 | 0.40 | 0.23 | 0.32 | 0.25 | 0.26 |
| Differential Pressure | 0.33 | 0.12 | 0.04 | 0.15 | 0.26 | 0.14 | 0.04 | -0.14 | -0.17 | 0.19 | 0.00 | 0.04 | 0.22 | -0.13 | -0.11 | -0.07 | 0.44 | -0.08 | -0.12 | 0.52 | -0.14 | -0.13 | 0.51 | 0.01 | 0.07 | -0.33 | -0.09 | -0.15 | -0.13 | -0.15 |
| Lab Temp | -0.44 | -0.28 | -0.14 | -0.23 | -0.32 | 0.08 | -0.01 | -0.14 | 0.20 | -0.49 | 0.26 | -0.01 | 0.20 | -0.21 | 0.11 | 0.17 | -0.30 | -0.10 | 0.13 | -0.25 | 0.11 | 0.11 | -0.21 | -0.23 | -0.20 | -0.13 | -0.23 | -0.17 | -0.22 | -0.22 |
| Lab % RH | 0.31 | 0.33 | 0.29 | 0.28 | 0.11 | 0.11 | 0.12 | 0.05 | 0.09 | 0.26 | -0.20 | -0.05 | 0.22 | 0.21 | -0.05 | 0.14 | 0.23 | -0.08 | 0.12 | 0.24 | 0.10 | 0.09 | 0.24 | 0.20 | 0.13 | 0.07 | 0.11 | 0.03 | 0.24 | 0.28 |
| Lab Press | 0.28 | 0.63 | 0.62 | 0.59 | 0.20 | -0.25 | -0.20 | 0.03 | 0.00 | -0.01 | -0.33 | -0.06 | -0.01 | 0.01 | -0.02 | 0.05 | 0.22 | -0.14 | 0.03 | 0.20 | 0.02 | 0.02 | 0.17 | 0.01 | -0.07 | -0.30 | 0.00 | 0.03 | 0.10 | 0.13 |
| WTM Water Temp | -0.29 | -0.10 | -0.13 | -0.15 | -0.33 | -0.07 | 0.08 | 0.23 | -0.07 | -0.17 | 0.26 | -0.13 | -0.09 | -0.29 | -0.11 | 0.04 | -0.15 | -0.15 | -0.05 | 0.05 | -0.10 | -0.10 | 0.13 | -0.22 | -0.11 | 0.02 | -0.17 | -0.18 | -0.24 | -0.27 |
| WTM WVP | -0.18 | -0.04 | -0.08 | -0.09 | -0.21 | -0.10 | 0.01 | 0.17 | -0.03 | -0.33 | 0.26 | -0.14 | -0.06 | -0.35 | -0.12 | 0.13 | -0.21 | -0.27 | 0.03 | -0.03 | -0.02 | -0.02 | 0.05 | -0.16 | -0.06 | -0.08 | -0.09 | -0.05 | -0.11 | -0.12 |
| Center HF | 0.58 | 0.16 | 0.00 | 0.08 | 0.57 | 0.14 | 0.01 | -0.19 | -0.21 | 0.05 | 0.05 | -0.08 | -0.13 | 0.37 | -0.15 | -0.29 | 0.19 | 0.25 | -0.26 | 0.13 | -0.24 | -0.24 | 0.09 | 0.14 | 0.17 | 0.08 | -0.03 | -0.21 | 0.01 | 0.03 |
| Top Left | -0.54 | -0.52 | -0.49 | -0.48 | -0.34 | 0.08 | 0.01 | -0.10 | -0.20 | -0.18 | 0.13 | 0.06 | 0.01 | -0.28 | -0.10 | 0.02 | -0.34 | -0.22 | 0.04 | -0.40 | 0.05 | 0.06 | -0.40 | -0.27 | -0.21 | -0.14 | 0.06 | 0.28 | -0.09 | -0.16 |
| Top Right | -0.43 | -0.17 | -0.27 | -0.15 | -0.29 | 0.00 | 0.05 | 0.09 | -0.41 | 0.20 | -0.18 | -0.08 | 0.12 | -0.19 | -0.43 | 0.16 | -0.15 | -0.61 | 0.13 | -0.25 | 0.11 | 0.11 | -0.26 | -0.02 | 0.04 | -0.20 | 0.31 | 0.48 | 0.17 | 0.11 |
| Low Right | -0.20 | 0.12 | 0.13 | 0.08 | -0.38 | 0.09 | 0.38 | 0.51 | 0.06 | -0.27 | 0.23 | 0.14 | -0.05 | -0.10 | 0.23 | -0.10 | -0.09 | 0.16 | -0.01 | -0.11 | 0.04 | 0.03 | -0.12 | -0.33 | -0.29 | 0.11 | -0.23 | -0.05 | -0.22 | -0.21 |
| Low Left | -0.41 | -0.36 | -0.30 | -0.35 | -0.43 | 0.00 | 0.05 | 0.08 | 0.11 | -0.45 | 0.29 | 0.06 | -0.09 | -0.27 | 0.16 | 0.04 | -0.29 | 0.01 | 0.09 | -0.23 | 0.12 | 0.13 | -0.20 | -0.35 | -0.31 | -0.02 | -0.24 | -0.10 | -0.28 | -0.30 |
| Cal Factor | 0.14 | 0.37 | 0.50 | 0.44 | 0.16 | -0.33 | -0.41 | -0.21 | 0.25 | 0.22 | -0.65 | -0.11 | 0.06 | 0.21 | 0.06 | 0.20 | 0.17 | -0.05 | 0.17 | 0.14 | 0.15 | 0.14 | 0.12 | 0.32 | 0.10 | -0.06 | 0.18 | 0.10 | 0.28 | 0.32 |
| CF Ratio | 0.06 | 0.23 | 0.38 | 0.32 | 0.12 | -0.34 | -0.45 | -0.26 | 0.27 | 0.17 | -0.62 | -0.11 | 0.03 | 0.18 | 0.07 | 0.23 | 0.11 | -0.07 | 0.17 | 0.10 | 0.14 | 0.14 | 0.10 | 0.32 | 0.11 | 0.01 | 0.17 | 0.07 | 0.27 | 0.31 |
| Kh (STP correction) | 0.37 | 0.66 | 0.72 | 0.68 | 0.37 | -0.15 | -0.11 | 0.03 | 0.11 | 0.19 | -0.40 | 0.08 | 0.19 | 0.15 | 0.09 | 0.05 | 0.45 | 0.00 | 0.11 | 0.39 | 0.14 | 0.13 | 0.31 | -0.01 | -0.16 | -0.44 | 0.00 | 0.01 | 0.04 | 0.05 |

Disappointed Engineer briefs team that little to no correlation is evident.



Data reduction suggested; focusing on individual manufacturers of OSU



Updated Correlation Table Isolated by Manufacturer

| Code | Manufacturer | Chamber CFM | Bypass CFM | Total CFM | Chamber SCFM | Bypass SCFM | Total SCFM | Min | Max | Delta | Bypass % | Chamber % | Ratio (3:1) | Airflow Temp | Airflow % RH |
|------|--------------|-------------|------------|-----------|--------------|-------------|------------|-------|-------|-------|----------|-----------|-------------|--------------|--------------|
| Ax | A | 19.63 | 62.18 | 81.81 | 19.21 | 60.84 | 80.05 | 81.47 | 82.33 | 0.85 | 0.76 | 0.24 | 3.17 | 72.70 | 18.23 |
| Ay | A | 20.35 | 57.35 | 77.70 | 20.56 | 57.95 | 78.51 | 77.70 | 77.70 | 0.00 | 0.74 | 0.26 | 2.82 | 74.40 | 8.00 |
| Az | A | 27.79 | 60.31 | 88.10 | 27.95 | 60.67 | 88.62 | 88.06 | 88.21 | 0.15 | 0.68 | 0.32 | 2.17 | 72.00 | 38.00 |

| | Bypass CFM | Total CFM | Chamber SCFM | Bypass SCFM | Total SCFM | Min | Max | Delta | Bypass % | Chamber % | Ratio (3:1) | Airflow Temp | Airflow % RH | Interspace Area | Lower Plenum | Press Ratio | Upstream Pressure | Downstream Pressure | Differential Pressure | Lab Temp | Lab % RH | Lab Press | WTM Water Temp | WTM WVP | Center HF | Top Left | Top Right | Low Right | Low Left | Cal Factor | CF Ratio | Kh (STP correction) | | | |
|-----------------------|------------|-----------|--------------|-------------|------------|------|------|-------|----------|-----------|-------------|--------------|--------------|-----------------|--------------|-------------|-------------------|---------------------|-----------------------|----------|----------|-----------|----------------|---------|-----------|----------|-----------|-----------|----------|------------|----------|---------------------|------|------|-------|
| Chamber CFM | 0.05 | -0.89 | 1.00 | 0.38 | 0.98 | 0.90 | 0.86 | -0.43 | -0.98 | 0.98 | -0.96 | -0.67 | 0.91 | -1.00 | -0.39 | -0.77 | 0.98 | 0.98 | 0.75 | -0.73 | 0.79 | 0.34 | -1.00 | -0.99 | -1.00 | -0.94 | 0.20 | 0.99 | -0.31 | -0.09 | -0.11 | -0.11 | 0.90 | | |
| Bypass CFM | | 0.51 | -0.01 | 0.94 | 0.27 | 0.48 | 0.55 | 0.88 | 0.16 | -0.16 | 0.22 | -0.78 | 0.45 | -0.13 | -0.94 | 0.60 | -0.13 | -0.16 | 0.70 | 0.65 | -0.58 | -0.92 | -0.13 | -0.16 | -0.13 | 0.28 | 0.99 | -0.31 | -0.09 | -0.11 | -0.11 | -0.40 | | | |
| Total CFM | | | 0.85 | 0.77 | 0.97 | 1.00 | 1.00 | 0.04 | -0.77 | 0.77 | -0.73 | -0.94 | 1.00 | -0.92 | -0.77 | -0.39 | 0.79 | 0.77 | 0.97 | -0.33 | 0.41 | -0.13 | -0.92 | -0.93 | -0.92 | -0.68 | 0.63 | -0.98 | -0.90 | 0.80 | 0.80 | 0.59 | | | |
| Chamber SCFM | | | | 0.32 | 0.96 | 0.87 | 0.83 | -0.48 | -0.99 | 0.99 | -0.98 | -0.62 | 0.88 | -0.99 | -0.33 | -0.81 | 0.99 | 0.99 | 0.70 | -0.77 | 0.82 | 0.40 | -0.99 | -0.99 | -0.99 | -0.96 | 0.14 | -0.94 | -0.99 | 1.00 | 1.00 | 0.92 | | | |
| Bypass SCFM | | | | | 0.57 | 0.74 | 0.80 | 0.67 | -0.18 | 0.18 | -0.12 | -0.94 | 0.73 | -0.45 | -1.00 | 0.29 | 0.21 | 0.17 | 0.90 | 0.35 | -0.27 | -0.74 | -0.45 | -0.48 | -0.45 | -0.05 | 0.98 | -0.61 | -0.42 | 0.23 | 0.23 | -0.07 | | | |
| Total SCFM | | | | | | 0.97 | 0.95 | -0.22 | -0.91 | 0.91 | -0.88 | -0.81 | 0.98 | -0.99 | -0.58 | -0.61 | 0.92 | 0.91 | 0.87 | -0.56 | 0.63 | 0.13 | -0.99 | -0.99 | -0.99 | -0.85 | 0.41 | -1.00 | -0.98 | 0.93 | 0.93 | 0.78 | | | |
| Min | | | | | | | 1.00 | 0.01 | -0.79 | 0.79 | -0.75 | -0.92 | 1.00 | -0.93 | -0.75 | -0.42 | 0.81 | 0.79 | 0.96 | -0.36 | 0.44 | -0.10 | -0.93 | -0.94 | -0.93 | -0.71 | 0.60 | -0.98 | -0.92 | 0.82 | 0.82 | 0.62 | | | |
| Max | | | | | | | | 0.09 | -0.74 | 0.74 | -0.69 | -0.95 | 0.99 | -0.90 | -0.80 | -0.34 | 0.76 | 0.73 | 0.98 | -0.28 | 0.36 | -0.18 | -0.90 | -0.91 | -0.90 | -0.64 | 0.67 | -0.97 | -0.88 | 0.77 | 0.77 | 0.55 | | | |
| Delta | | | | | | | | | 0.60 | -0.60 | 0.65 | -0.39 | -0.02 | 0.35 | -0.67 | 0.90 | -0.58 | -0.61 | 0.28 | 0.93 | -0.89 | -1.00 | 0.35 | 0.33 | 0.35 | 0.70 | 0.80 | 0.17 | 0.39 | -0.56 | -0.56 | -0.78 | | | |
| Bypass % | | | | | | | | | | -1.00 | 1.00 | 0.50 | -0.81 | 0.96 | 0.19 | 0.89 | -1.00 | -1.00 | -0.59 | 0.86 | -0.90 | -0.53 | 0.96 | 0.95 | 0.96 | 0.99 | 0.01 | 0.89 | 0.97 | -1.00 | -1.00 | -0.97 | | | |
| Chamber % | | | | | | | | | | | -1.00 | -0.50 | 0.81 | -0.96 | -0.19 | -0.89 | 1.00 | 1.00 | 0.59 | -0.86 | 0.90 | 0.53 | -0.96 | -0.95 | -0.96 | -0.99 | -0.01 | -0.89 | -0.97 | 1.00 | 1.00 | 0.97 | | | |
| Ratio (3:1) | | | | | | | | | | | | 0.44 | -0.77 | 0.94 | 0.12 | 0.91 | -1.00 | -1.00 | -0.54 | 0.89 | -0.92 | -0.58 | 0.94 | 0.93 | 0.94 | 1.00 | 0.07 | 0.86 | 0.95 | -0.99 | -0.99 | -0.98 | | | |
| Airflow Temp | | | | | | | | | | | | | -0.91 | 0.73 | 0.94 | 0.04 | -0.52 | -0.49 | -0.99 | -0.02 | -0.06 | 0.47 | 0.73 | 0.74 | 0.73 | 0.38 | -0.86 | 0.84 | 0.70 | -0.54 | -0.54 | -0.27 | | | |
| Airflow % RH | | | | | | | | | | | | | | -0.94 | -0.73 | -0.44 | 0.82 | 0.80 | 0.95 | -0.39 | 0.46 | -0.07 | -0.94 | -0.95 | -0.94 | -0.72 | 0.58 | -0.99 | -0.93 | 0.84 | 0.84 | 0.64 | | | |
| Interspace Area | | | | | | | | | | | | | | | 0.46 | 0.72 | -0.97 | -0.96 | -0.80 | 0.67 | -0.73 | -0.27 | 1.00 | 1.00 | 1.00 | 0.91 | -0.28 | 0.98 | 1.00 | -0.97 | -0.97 | -0.86 | | | |
| Lower Plenum | | | | | | | | | | | | | | | | -0.29 | -0.21 | -0.18 | -0.90 | -0.35 | 0.27 | 0.73 | 0.46 | 0.48 | 0.46 | 0.06 | -0.98 | 0.62 | 0.43 | -0.23 | -0.24 | 0.06 | | | |
| Press Ratio | | | | | | | | | | | | | | | | | -0.87 | -0.89 | -0.15 | 1.00 | -1.00 | -0.86 | 0.72 | 0.70 | 0.72 | 0.94 | 0.47 | 0.57 | 0.74 | -0.86 | -0.86 | -0.97 | | | |
| Upstream Pressure | | | | | | | | | | | | | | | | | | | | | 1.00 | 0.61 | -0.84 | 0.88 | 0.51 | -0.97 | -0.96 | -0.97 | -0.99 | 0.02 | -0.90 | -0.98 | 1.00 | 1.00 | 0.96 |
| Downstream Pressure | | | | | | | | | | | | | | | | | | | | | | 0.59 | -0.86 | 0.90 | 0.54 | -0.96 | -0.95 | -0.96 | -0.99 | -0.01 | -0.88 | -0.97 | 1.00 | 1.00 | 0.97 |
| Differential Pressure | | | | | | | | | | | | | | | | | | | | | | | -0.09 | 0.17 | -0.37 | -0.80 | -0.81 | -0.80 | -0.48 | 0.80 | -0.90 | -0.77 | 0.63 | 0.63 | 0.38 |
| Lab Temp | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.96 |
| Lab % RH | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.98 |
| Lab Press | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | 0.72 |
| WTM Water Temp | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.86 |
| WTM WVP | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.85 |
| Center HF | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.86 |
| Top Left | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | -0.99 |

Much more correlation exists than when reviewing industry as a whole



Updated Correlation Table Isolated by Manufacturer

| Code | Manufacturer | Chamber CFM | Bypass CFM | Total CFM | Chamber SCFM | Bypass SCFM | Total SCFM | Min | Max | Delta | Bypass % | Chamber % | Ratio (3:1) | Airflow Temp | Airflow % RH |
|------|--------------|-------------|------------|-----------|--------------|-------------|------------|-------|-------|-------|----------|-----------|-------------|--------------|--------------|
| Bw | B | 21.93 | 67.37 | 89.30 | 21.40 | 65.74 | 87.14 | 88.65 | 89.84 | 1.18 | 0.75 | 0.25 | 3.07 | 72.76 | 35.37 |
| Bx | B | 27.03 | 64.76 | 91.79 | 27.05 | 64.81 | 91.86 | 90.69 | 92.50 | 1.81 | 0.71 | 0.29 | 2.40 | 71.48 | 2.21 |
| By | B | 24.55 | 74.76 | 99.31 | 23.89 | 72.74 | 96.63 | 99.20 | 99.38 | 0.19 | 0.75 | 0.25 | 3.04 | 70.34 | 1.55 |
| Bz | B | 20.99 | 66.06 | 87.05 | 21.07 | 66.30 | 87.37 | 86.47 | 87.62 | 1.15 | 0.76 | 0.24 | 3.15 | 70.21 | 43.05 |

| | PHR | PHR CV | PHR mV Rise | TTP | TTP CV | Rate of Rise | Rate of Fall | 2 Min THR | 2 Min THR CV | PHR/THR Ratio | 5 Min THR | 5 Min THR CV | THR Delta | Ending Avg HRR | Ending Avg HRR CV | PHR | PHR mV Rise | TTP | 2 Min THR | PHR/THR Ratio | 5 Min THR | THR Delta |
|-----------------------|-------|--------|-------------|-------|--------|--------------|--------------|-----------|--------------|---------------|-----------|--------------|-----------|----------------|-------------------|-------|-------------|-------|-----------|---------------|-----------|-----------|
| Chamber CFM | -0.63 | 0.86 | -0.26 | 0.91 | 0.82 | -0.99 | -0.44 | -0.49 | -0.67 | -0.55 | -0.45 | -0.80 | -0.41 | -0.42 | -0.83 | -0.87 | -1.00 | -0.98 | 0.86 | 1.00 | -0.65 | -0.84 |
| Bypass CFM | -0.71 | 0.80 | -0.37 | 0.86 | 0.75 | -1.00 | -0.54 | -0.59 | -0.76 | -0.45 | -0.55 | -0.86 | -0.52 | -0.52 | -0.89 | -0.92 | -0.99 | -0.95 | 0.79 | 0.99 | -0.73 | -0.90 |
| Total CFM | -0.69 | 0.82 | -0.34 | 0.87 | 0.77 | -1.00 | -0.52 | -0.56 | -0.73 | -0.48 | -0.52 | -0.85 | -0.49 | -0.49 | -0.88 | -0.91 | -0.99 | -0.96 | 0.81 | 0.99 | -0.71 | -0.88 |
| Chamber SCFM | -0.74 | 0.78 | -0.40 | 0.84 | 0.73 | -1.00 | -0.57 | -0.62 | -0.78 | -0.42 | -0.58 | -0.88 | -0.55 | -0.55 | -0.91 | -0.94 | -0.98 | -0.94 | 0.77 | 0.98 | -0.75 | -0.91 |
| Bypass SCFM | -1.00 | 1.00 | -1.00 | 1.00 | 1.00 | -1.00 | -1.00 | -1.00 | -1.00 | 1.00 | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 | 1.00 | 1.00 | -1.00 | -1.00 |
| Total SCFM | -0.82 | 0.69 | -0.52 | 0.76 | 0.63 | -0.99 | -0.67 | -0.71 | -0.85 | -0.30 | -0.68 | -0.93 | -0.65 | -0.65 | -0.95 | -0.97 | -0.94 | -0.89 | 0.68 | 0.95 | -0.83 | -0.96 |
| Min | -0.70 | 0.81 | -0.35 | 0.87 | 0.76 | -1.00 | -0.53 | -0.57 | -0.74 | -0.47 | -0.53 | -0.85 | -0.50 | -0.51 | -0.88 | -0.92 | -0.99 | -0.96 | 0.80 | 0.99 | -0.72 | -0.89 |
| Max | -0.69 | 0.82 | -0.34 | 0.88 | 0.77 | -1.00 | -0.51 | -0.56 | -0.73 | -0.48 | -0.52 | -0.84 | -0.49 | -0.49 | -0.87 | -0.91 | -0.99 | -0.96 | 0.81 | 0.99 | -0.71 | -0.88 |
| Delta | 0.82 | -0.68 | 0.53 | -0.76 | -0.63 | 0.99 | 0.68 | 0.72 | 0.86 | 0.29 | 0.69 | 0.94 | 0.66 | 0.66 | 0.96 | 0.98 | 0.94 | 0.88 | -0.67 | -0.95 | 0.84 | 0.96 |
| Bypass % | 0.15 | -1.00 | -0.26 | -0.99 | -1.00 | 0.80 | -0.07 | -0.01 | 0.21 | 0.90 | -0.06 | 0.39 | -0.10 | -0.09 | 0.44 | 0.51 | 0.89 | 0.95 | -1.00 | -0.88 | 0.18 | 0.46 |
| Chamber % | -0.15 | 1.00 | 0.26 | 0.99 | 1.00 | -0.80 | 0.07 | 0.01 | -0.21 | -0.90 | 0.06 | -0.39 | 0.10 | 0.09 | -0.44 | -0.51 | -0.89 | -0.95 | 1.00 | 0.88 | -0.18 | -0.46 |
| Ratio (3:1) | 0.15 | -1.00 | -0.26 | -0.99 | -1.00 | 0.79 | -0.07 | -0.02 | 0.21 | 0.90 | -0.06 | 0.39 | -0.10 | -0.10 | 0.44 | 0.50 | 0.89 | 0.94 | -1.00 | -0.88 | 0.17 | 0.45 |
| Airflow Temp | 0.90 | 0.30 | 1.00 | 0.20 | 0.37 | 0.34 | 0.97 | 0.96 | 0.87 | -0.69 | 0.97 | 0.76 | 0.98 | 0.98 | 0.72 | 0.67 | 0.17 | 0.03 | 0.32 | -0.19 | 0.89 | 0.71 |
| Airflow % RH | 0.69 | -0.82 | 0.34 | -0.87 | -0.77 | 1.00 | 0.51 | 0.56 | 0.73 | 0.48 | 0.52 | 0.85 | 0.49 | 0.49 | 0.88 | 0.91 | 0.99 | 0.96 | -0.81 | -0.99 | 0.71 | 0.88 |
| Interspace Area | 0.92 | 0.26 | 1.00 | 0.16 | 0.33 | 0.38 | 0.98 | 0.97 | 0.89 | -0.66 | 0.98 | 0.79 | 0.99 | 0.99 | 0.75 | 0.70 | 0.21 | 0.07 | 0.27 | -0.23 | 0.91 | 0.74 |
| Lower Plenum | -0.75 | -0.55 | -0.95 | -0.46 | -0.61 | -0.07 | -0.87 | -0.84 | -0.70 | 0.86 | -0.87 | -0.56 | -0.89 | -0.89 | -0.51 | -0.44 | 0.11 | 0.24 | -0.56 | -0.08 | -0.73 | -0.50 |
| Press Ratio | 0.90 | 0.29 | 1.00 | 0.19 | 0.36 | 0.35 | 0.98 | 0.96 | 0.87 | -0.68 | 0.97 | 0.77 | 0.98 | 0.98 | 0.73 | 0.68 | 0.18 | 0.04 | 0.31 | -0.20 | 0.89 | 0.72 |
| Upstream Pressure | 0.68 | 0.62 | 0.92 | 0.54 | 0.68 | -0.02 | 0.83 | 0.79 | 0.63 | -0.90 | 0.82 | 0.48 | 0.84 | 0.84 | 0.43 | 0.36 | -0.20 | -0.33 | 0.63 | 0.17 | 0.66 | 0.41 |
| Downstream Pressure | 0.36 | -0.98 | -0.05 | -0.99 | -0.96 | 0.91 | 0.14 | 0.20 | 0.42 | 0.78 | 0.15 | 0.58 | 0.12 | 0.12 | 0.62 | 0.68 | 0.97 | 0.99 | -0.97 | -0.96 | 0.38 | 0.64 |
| Differential Pressure | -0.13 | 1.00 | 0.28 | 0.99 | 1.00 | -0.78 | 0.09 | 0.03 | -0.19 | -0.90 | 0.08 | -0.37 | 0.12 | 0.11 | -0.42 | -0.49 | -0.88 | -0.94 | 1.00 | 0.87 | -0.16 | -0.44 |
| Lab Temp | 0.86 | -0.63 | 0.58 | -0.71 | -0.57 | 0.97 | 0.73 | 0.77 | 0.89 | 0.22 | 0.73 | 0.96 | 0.71 | 0.71 | 0.97 | 0.99 | 0.92 | 0.85 | -0.62 | -0.92 | 0.87 | 0.98 |
| Lab % RH | 0.81 | -0.71 | 0.50 | -0.78 | -0.65 | 0.99 | 0.66 | 0.70 | 0.84 | 0.32 | 0.66 | 0.93 | 0.63 | 0.64 | 0.95 | 0.97 | 0.95 | 0.90 | -0.70 | -0.96 | 0.82 | 0.95 |
| Lab Press | 0.12 | -1.00 | -0.29 | -0.99 | -1.00 | 0.78 | -0.10 | -0.05 | 0.18 | 0.91 | -0.09 | 0.36 | -0.13 | -0.13 | 0.41 | 0.48 | 0.87 | 0.93 | -1.00 | -0.86 | 0.14 | 0.43 |
| WTM Water Temp | 0.87 | 0.36 | 0.99 | 0.26 | 0.43 | 0.28 | 0.96 | 0.94 | 0.84 | -0.73 | 0.95 | 0.72 | 0.97 | 0.96 | 0.68 | 0.63 | 0.11 | -0.03 | 0.37 | -0.13 | 0.86 | 0.67 |
| WTM WVP | 0.78 | -0.73 | 0.47 | -0.80 | -0.68 | 0.99 | 0.63 | 0.67 | 0.82 | 0.35 | 0.64 | 0.91 | 0.61 | 0.61 | 0.93 | 0.96 | 0.96 | 0.91 | -0.72 | -0.97 | 0.80 | 0.94 |

Much more correlation exists than when reviewing industry as a whole



Recommended Next Steps:

- Excellent work by FAA/Industry teams capturing individual OSU data for 2016 Round Robin. However, at the time of authoring this presentation, no definitive conclusion can be made.
- Observation that significant variability still exists among machines; perhaps due to manufacturing or operational differences.
- Recommend to complete 2016 Round Robin testing and continue data analysis.
- Discussion for next steps to follow in task group

Merci pour votre attention et la participation !