



# Analysis of HR2 DOE II Results

## (Data Collected at FAA Tech Center)

International Aircraft Materials Fire Test Working Group  
Atlantic City, NJ  
30 October 2017

Thomas W. Little, Ph.D.  
Boeing Commercial Airplanes

### Acknowledgements

FAA Tech Center: Mike Burns

Boeing: Yaw Agyei, Yonas Behboud, Brian E. Johnson

# HR2 DOE II Results

---

## ▪ Objective

- Evaluate effect of tolerance ranges of machine input parameters on output variation
- Compare results of HR2 DOE I (2015) and DOE II (2017)

## ▪ Background

- June 2015 FTWG HR2 Task Group: Boeing proposed preliminary screening DOE, without test coupons, to determine relative effect of the tolerance range of certain HR2 machine parameters on the thermopile output
- August-September 2015: Preliminary screening DOE run at FAA Tech Center
  - Machine parameters: chamber airflow, center heat flux, upper pilot flame methane flow, upper pilot flame airflow
  - Data analyzed by Boeing (Yusuf Mansour) & data presented at March 2016 FTWG (Matt Anglin)
- As a result of the screening DOE, the tolerance ranges for the following parameters were tightened considerably through HR2 hardware modifications
  - Chamber airflow:  $20 \pm 1$  ->  $20.0 \pm 0.4$  SCFM
  - Upper Pilot Flame Methane Flow:  $1.50 \pm 0.20$  ->  $1.50 \pm 0.03$  SLPM
  - Upper Pilot Flame Airflow:  $1.00 \pm 0.20$  ->  $1.00 \pm 0.03$  SLPM
- September 2017: Screening DOE re-run at FAA Tech Center (“DOE II”) with Boeing assistance
  - Dates of DOE II experiment: 19-21 September 2017

# HR2 DOE II Results

## DOE Description

- 4-factor, 3-level experiment
  - Response variable: Thermopile reading (deg C)
  - Symmetric high/low values around center point for each factor
- Factors:
  - Center heat flux:  $3.65 \pm 0.05$  W/cm<sup>2</sup>
  - Chamber airflow:  $20 \pm 0.4$  SCFM
  - Upper Pilot Flame Methane:  $1.50 \pm 0.03$  SLPM
  - Upper Pilot Flame Airflow:  $1.00 \pm 0.05$  SLPM
- Experimental Procedure
  - Reference: M. Burns, "Heat Release Rate Updates," June 2017 Materials Fire Test Working Group Meeting (Cologne, GER)
  - 3 types of experimental runs:
    - Calibration runs (once per "day")
    - Stability runs
      - Center point controls: 2x per day
      - Stabilize new heat flux & chamber airflow: 1x per day (not shown)
    - Test runs (4x per day): factors @ DOE settings
  - No randomization of test conditions and no replicates for a given set of 4-factors
  - Note: "Day 2" & "Day 3" are actually the same day (20SEP2017)

Day	Data Point	Chamber Airflow (SCFM)	Center Heat Flux (W/cm <sup>2</sup> )	Upper Pilot Flame Methane (SLPM)	Upper Pilot Flame Airflow (SLPM)
1	Cal	20.0	-	-	-
1	Pre	20.0	3.65	1.50	1.00
1	2	19.6	3.60	1.47	0.95
1	3	19.6	3.60	1.47	1.05
1	4	19.6	3.60	1.53	1.05
1	5	19.6	3.60	1.53	0.95
1	Post	20.0	3.65	1.50	1.00
2	Cal	20.0	-	-	-
2	Pre	20.0	3.65	1.50	1.00
2	2	19.6	3.70	1.47	0.95
2	3	19.6	3.70	1.47	1.05
2	4	19.6	3.70	1.53	1.05
2	5	19.6	3.70	1.53	0.95
2	Post	20.0	3.65	1.50	1.00
3	Cal	20.0	-	-	-
3	Pre	20.0	3.65	1.50	1.00
3	2	20.4	3.60	1.47	0.95
3	3	20.4	3.60	1.47	1.05
3	4	20.4	3.60	1.53	1.05
3	5	20.4	3.60	1.53	0.95
3	Post	20.0	3.65	1.50	1.00
4	Cal	20.0	-	-	-
4	Pre	20.0	3.65	1.50	1.00
4	2	20.4	3.70	1.47	0.95
4	3	20.4	3.70	1.47	1.05
4	4	20.4	3.70	1.53	1.05
4	5	20.4	3.70	1.53	0.95
4	Post	20.0	3.65	1.50	1.00

# HR2 DOE II Results

---

## ■ DOE Description

- Several notable differences between conditions for DOE I and DOE II

### Comparison of Experimental Conditions for DOE I and DOE II

Item	DOE I (Fall 2015)	DOE II (Fall 2017)
<b>Hardware</b>		
Chamber Air	Mass Flow Meter	Mass Flow Controller
Upper Pilot Air	Volumetric Flow Meter	Mass Flow Controller
Thermopile TCs	5 hot, 5 reference	5 hot, 1 reference
<b>Calibration</b>		
Methodology	Step Method	Ramp Method
Thermopile Output	Voltage (mV)	Temperature (deg C)
<b>Parameters</b>		
Center Heat Flux (W/cm <sup>2</sup> )	3.60 - 3.70	3.60 - 3.70
Chamber Airflow (SCFM)	19.0 - 21.0	19.6 - 20.4
Upper Pilot Flame Methane(SLPM)	1.30 - 1.70	1.47 - 1.53
Upper Pilot Flame Airflow (SLPM)	0.8 - 1.2	0.95 - 1.05
<b>Experimental Duration</b>	4 days	3 days
<b>Stability Run Data Collection</b>	> 10 minutes	1 minute after Std Dev < 2%

## HR2 DOE II Data

- **Calibration Runs**
- **Stability Runs**
- **Factor Effects**


# HR2 DOE II Results

## Calibration Runs

- Determination of cal factor ( $K_h$ ) (unit = W/deg C)

$$K_h = \frac{(210.8-22)kCal * mol(CH_4)}{mol * 22.41L} * \frac{Watt * min}{0.01433 kCal} * \frac{1000W}{1000W} * \frac{\Delta F}{\Delta^\circ C}$$

- $K_h = \text{constant} * (\Delta F / \Delta T)$
- $(\Delta F / \Delta T) = (1 / \text{slope})$
- "Cal factor must be in the range of  $17 \pm 2$  W/deg C"
- Cal factor ( $K_h$ ) variation: ~2.2%
  - Occurs within a single "day"
    - "Day 2" & "Day 3" actually the same day (20SEP2017)
    - 0.3% variation with outlier removed
- Cal factor directly reflected in HRR
  - Assuming all other factors constant



Day	Date	[1/Slope] (L/min/C)	Cal Factor (W/deg C)
1	19-Sep	0.0319	18.75
2	20-Sep	0.0319	18.75
3	20-Sep	0.0326	19.17
4	21-Sep	0.0320	18.81

$$\text{Heat Release Rate} = (T_{\text{pile}_C} - BL_C) * \frac{K_h \div 1000}{0.02323} \text{ kW/m}^2$$


## HR2 DOE II Data

- Calibration Runs
- **Stability Runs**
- Factor Effects

# HR2 DOE II Results

## ■ Stability Runs (Center Point Controls)

- Collected twice per day
  - Pre and Post test data collection (beginning and end of each day's data collection)
- Collected at factor center points
  - Flux 3.65 W/cm<sup>2</sup>, Chamber Air 20.0 SCFM, Upper Methane 1.50 SLPM, Upper Air 1.00 SLPM
  - Each data set consists of 1 minute of data acquired at 1 sec intervals → 60 data points





# HR2 DOE II Results

## Stability Runs

### Analysis of Variance (ANOVA)

Source	DF	Adj SS	Adj MS	F-Value	P-Value
Data Set	7	118.8	16.9669	18.52	0.000
Error	472	432.4	0.9162		
Total	479	551.2			

Data Set	N	Mean	StDev	95% CI
1	60	277.862	1.017	(277.619, 278.104)
2	60	278.770	0.916	(278.527, 279.013)
3	60	279.010	0.954	(278.767, 279.253)
4	60	277.545	0.892	(277.302, 277.788)
5	60	277.772	0.974	(277.529, 278.014)
6	60	277.938	1.025	(277.696, 278.181)
7	60	277.893	0.945	(277.651, 278.136)
8	60	278.543	0.926	(278.301, 278.786)

Pooled StDev = 0.957175

Grouping Information Using the Tukey Method and 95% Confidence



Data Set	N	Mean	Grouping
3	60	279.010	A
2	60	278.770	A
8	60	278.543	A
6	60	277.938	B
7	60	277.893	B
1	60	277.862	B
5	60	277.772	B
4	60	277.545	B

**Effect Size Calculation (Example)**  
 $\text{Max } D = (279.01 - 277.55) / 0.96 = 1.52$

-> Sizeable difference

Means that do not share a letter are significantly different.

- Statistical difference among stability run average temperatures.
- Reason unclear. May be discernible upon further investigation.




## HR2 DOE II Data

- Calibration Runs
- Stability Runs
- **Factor Effects**

# HR2 DOE II Results

## Factor Effects


- Assessment of machine tolerance ranges: heat flux, chamber airflow, upper methane flow, upper air flow
- [Overview](#)



# HR2 DOE II Results

## Factor Effects


- **Heat Flux:**  $3.65 \pm 0.05 \text{ W/cm}^2$
- “Moderate” impact:  $\Delta T$  approximately -2 to +3 deg C for full-scale swing of  $3.60 \rightarrow 3.70 \text{ W/cm}^2$



# HR2 DOE II Results

## Factor Effects


- Chamber Airflow:  $20 \pm 0.4$  SCFM
- “Large” impact:  $\Delta T$  approximately -5 to -9 deg C for full-scale swing of 19.6 -> 20.4 SCFM



# HR2 DOE II Results

## Factor Effects


- **Upper Pilot Methane Flow:**  $1.50 \pm 0.03$  SLPM
- “Large” impact:  $\Delta T$  approximately +5 deg C for full-scale swing of 1.47 -> 1.53 SLPM



# HR2 DOE II Results

## Factor Effects

- **Upper Pilot Airflow**:  $1.00 \pm 0.005$  SLPM
- “Slight” impact:  $\Delta T$  approximately  $-0.4$  to  $+2$  deg C for full-scale swing of  $0.95 \rightarrow 1.05$  SLPM



# HR2 DOE II Results

---

## ▪ Factor Effects Summary

### – Assessment of machine tolerance ranges

- Heat flux: Moderate effect
- Chamber airflow: Large effect
- Upper methane flow: Large effect
- Upper air flow: Slight effect

### – Overall impact



- Evaluate maximum temperature swing over combined tolerance ranges
  - Condition for Maximum Temperature
    - Chamber airflow 19.6 SCFM, Heat flux 3.70 W/cm<sup>2</sup>, Upper methane 1.53 SLPM, Upper airflow 0.95 SLPM
    - Average temperature: 348 deg C
  - Condition for Minimum Temperature
    - Chamber airflow 20.4 SCFM, Heat flux 3.60 W/cm<sup>2</sup>, Upper methane 1.47 SLPM, Upper airflow 0.95 SLPM
    - Average temperature: 334 deg C
- Swing of average temperature over combined tolerance ranges: ~14 deg C or ~4.1%



# HR2 DOE II Results

## Factor Effects Summary: Contour Plots

- Assessment of machine tolerance ranges
  - Chamber Airflow & Upper Methane Flow: Large effects
- Overall impact
  - Swing of average temperature over combined tolerance ranges: ~14 deg C or ~4.1%



# HR2 DOE II Results

## ■ DOE I vs DOE II Comparison

- As noted earlier, there have been several significant changes in hardware and methodology in going from DOE I (Fall 2015) to DOE II (Fall 2017).
- As a result, direct numerical comparisons between the results of DOE I and DOE II are not straightforward.
- Additionally, both DOEs were limited in scope and represent a brief snap-shot in time.
- Disclaimers aside, however, the results of DOE II seem quite promising as shown in the table below.
- The various changes appear to have resulted in significant improvements in **calibration factor variation**, **uniformity of stability runs**, and **maximum variation over the range of allowed tolerance ranges**.

Item	DOE I (Fall 2015)	DOE II (Fall 2017)	Improvement? (Y/N)
Variation in Calibration Factors (%)	5.8	2.2 (0.3)	Y
Uniformity of Stability Runs (Max D)	3.5	1.5	Y
Factor Effect Impacts			
Heat Flux	Moderate	Moderate	--
Chamber Airflow	Large	Large	--
Upper Pilot Methane Flow	Large	Large	--
Upper Pilot Airflow	Slight	Slight	--
Maximum Response Variation (%)	13.1	4.1	Y

## ■ Screening DOE Summary

- DOEs I & II have successfully identified significant “knobs” for reduction in heat release variation and implementation of actions resulting from the screening DOEs seem to have yield significant improvements toward the end-goal of reducing variation in heat release measurements.

## Backup

# HR2 DOE II Results

## Factor Effects

- Assessment of machine tolerance ranges: heat flux, chamber airflow, upper methane flow, upper air flow
- Summary statistics

**Chamber Airflow (SCFM) = 19.6, Center Heat Flux (W/cm<sup>2</sup>) = 3.60, Upper Pilot Methane (SLPM) = 1.47**

Variable	Upper Pilot Airflow		Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Total Count							
Thermopile T (deg C)	0.95	60	340.90	0.122	0.944	0.28	339.20	340.80	343.30
	1.05	60	341.11	0.147	1.14	0.33	337.60	341.20	343.60

**Chamber Airflow (SCFM) = 19.6, Center Heat Flux (W/cm<sup>2</sup>) = 3.60, Upper Pilot Methane (SLPM) = 1.53**

Variable	Upper Pilot Airflow		Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Total Count							
Thermopile T (deg C)	0.95	60	346.36	0.124	0.958	0.28	344.50	346.40	348.60
	1.05	60	346.01	0.137	1.06	0.31	343.10	346.00	348.00

**Chamber Airflow (SCFM) = 19.6, Center Heat Flux (W/cm<sup>2</sup>) = 3.70, Upper Pilot Methane (SLPM) = 1.47**

Variable	Upper Pilot Airflow		Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Total Count							
Thermopile T (deg C)	0.95	60	343.66	0.148	1.15	0.33	340.50	343.75	346.10
	1.05	60	345.13	0.125	0.972	0.28	343.20	345.20	347.70

**Chamber Airflow (SCFM) = 19.6, Center Heat Flux (W/cm<sup>2</sup>) = 3.70, Upper Pilot Methane (SLPM) = 1.53**

Variable	Upper Pilot Airflow		Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Total Count							
Thermopile T (deg C)	0.95	60	348.08	0.136	1.05	0.30	345.80	348.00	350.20
	1.05	60	348.03	0.146	1.13	0.33	344.00	348.00	349.70

# HR2 DOE II Results

## Factor Effects

### Summary statistics

**CENTER POINTS Chamber Airflow (SCFM) = 20.0, Center Heat Flux (W/cm2) = 3.65, Upper Pilot Methane (SLPM) = 1.50**

Variable	Upper Pilot Airflow		Total	Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Count								
Thermopile T (deg C)	1.00	480		340.26	0.0835	1.83	0.54	335.50	340.20	344.60

**Chamber Airflow (SCFM) = 20.4, Center Heat Flux (W/cm2) = 3.60, Upper Pilot Methane (SLPM) = 1.47**

Variable	Upper Pilot Airflow		Total	Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Count								
Thermopile T (deg C)	0.95	60		334.27	0.139	1.08	0.32	330.80	334.35	336.80
	1.05	60		337.28	0.167	1.29	0.38	335.00	337.05	340.70

**Chamber Airflow (SCFM) = 20.4, Center Heat Flux (W/cm2) = 3.60, Upper Pilot Methane (SLPM) = 1.53**

Variable	Upper Pilot Airflow		Total	Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Count								
Thermopile T (deg C)	0.95	60		341.18	0.138	1.07	0.31	337.80	341.25	344.20
	1.05	60		340.48	0.129	0.999	0.29	338.10	340.65	342.30

**Chamber Airflow (SCFM) = 20.4, Center Heat Flux (W/cm2) = 3.70, Upper Pilot Methane (SLPM) = 1.47**

Variable	Upper Pilot Airflow		Total	Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Count								
Thermopile T (deg C)	0.95	60		334.57	0.130	1.01	0.30	331.20	334.55	336.60
	1.05	60		336.75	0.136	1.05	0.31	333.20	337.00	338.40


**Chamber Airflow (SCFM) = 20.4, Center Heat Flux (W/cm2) = 3.70, Upper Pilot Methane (SLPM) = 1.53**

Variable	Upper Pilot Airflow		Total	Mean	SE Mean	StDev	CoefVar	Minimum	Median	Maximum
	(SLPM)	Count								
Thermopile T (deg C)	0.95	60		338.98	0.122	0.943	0.28	336.80	338.80	341.60
	1.05	60		339.11	0.115	0.888	0.26	336.60	339.30	340.40

# HR2 DOE II Results

## Calibration (DOE I, Fall 2015)

Calibration Curve for 4 Different Days



day	Cal factor	% difference from mean	Pressure (milibar)	Room temp (F)	Room RH (%)	Inlet air RH(%)
1	0.091	3.88%	1020	79.2	50	11.82
2	0.088	0.34%	1018	81	54	14.02
3	0.086	-2.17%	1014	81.1	53	13.4
4	0.086	-2.05%	1020	80.2	55	12.69

There is ~6% spread in in cal factor (same machine, same lab, same operator... etc.), which will directly result in a 6% spread in the heat release rate assuming all other factors are constant

$$\text{Heat Release Rate} = (\text{Test}_{mV} - \text{Baseline}_{mV}) * \left( \frac{K_h}{0.02323} \right)$$

# HR2 DOE II Results

## ■ Stability Runs (DOE I, Fall 2015)

– Analysis of Variance (ANOVA)

Source	DF	Adj SS	Adj MS	F-Value	P-Value
Data Set	7	2044	292.004	1927.24	0.000
Error	15438	2339	0.152		
Total	15445	4383			

Data Set	N	Mean	StDev	95% CI
1	645	52.5992	0.2454	(52.5691, 52.6292)
2	1158	53.0500	0.2320	(53.0276, 53.0724)
3	983	53.8916	0.2679	(53.8673, 53.9160)
4	1235	53.5386	0.3114	(53.5169, 53.5603)
5	2829	53.1484	0.3041	(53.1340, 53.1627)
6	2047	53.3645	0.3805	(53.3477, 53.3814)
7	3243	53.2487	0.2731	(53.2353, 53.2621)
8	3306	53.9432	0.6146	(53.9299, 53.9564)

Pooled StDev = 0.389248

Grouping Information Using the Tukey Method and 95% Confidence

Data Set	N	Mean	Grouping
8	3306	53.9432	A
3	983	53.8916	B
4	1235	53.5386	C
6	2047	53.3645	D
7	3243	53.2487	E
5	2829	53.1484	F
2	1158	53.0500	G
1	645	52.5992	H

**Effect Size Calculation (Example)**  
 $\text{Max } D = (53.9432 - 52.5992) / 0.39 = 3.45$

Means that do not share a letter are significantly different.

- Statistical difference among stability run average temperatures.
- All stability run data included, not just last 1 minute after stabilization

