

Experimental Investigation of the Park Burner, Comparisons to NexGen

Ryan Hasselbeck and San-Mou Jeng

Fire Test Center

University of Cincinnati, Cincinnati, OH, USA

Project Overview

- Project Objective:
 - Demonstrate the 2000 F minimum average temperature requirement drives heat flux to upper bound
 - Draw comparisons between the calibration and burn-through of Park vs NexGen Burners
- Previous Work on NexGen burner development:
 - Effect of burner setup, assembly tolerances and calibration TC size
 - Effect of burner orientation on performance
 - Burner sensitivity to operating conditions
 - Air and fuel flowrate
 - Air and fuel temperature
 - Comparison of fire test results between NexGen and Gas burner

Liquid Burner




Gas Burner



Liquid Burner Overview


Park Burner



Monarch 2.25 GPH, 80 Degree PLP



NexGen Burner




Delevan 2.5 GPH, 80 Degree Type W



- Same fuel (Jet-A) and burner cone
 - NexGen burner: both fuel and air flow rate are controlled and metered
 - Park burner: only fuel flow rate is controlled and metered

Air Velocities – Park vs NexGen

- Park burner air mass flow can not adjustable/controlled.
- Park burner: 15-20% less air velocity (exit of tube)
- Measured with hot wire probe



Average Air Velocities (ft/min)	
	Exit of Tube
Park	674
NexGen	780

Fire Test Setup

- Temperature calibration: 1/8", Type K exposed bead Thermocouples
- Heat Flux: copper pipe with water flows
- Burn-through tests: 24"x24"x0.125" panel (2024 Aluminum)



Figure 1: TC Rake



Figure 2: Al Panel






Figure 3: Heat Flux Tube

Park Burner Results


1" Temperature vs Fuel Flow Rate



Burn Through Time vs Fuel Flow Rate




1" Heat Flux vs Fuel Flow Rate




- 1.75-2.3 gph fuel flow rate
- More severe fire with higher fuel flow rate
- ~2000 degrees F, heat flux has reached the upper limit (per ISO 2685)
- Our experience – very difficult to satisfy calibration requirement

NexGen Burner Results


1" Temperature vs Fuel Flow Rate



Burn Through Time vs Fuel Flow Rate



1" Heat Flux vs Fuel Flow Rate




- 2.0-2.7 gph fuel flow rate (10-15% higher than Park)
- Fixed air flow rate (~15% higher than Park roughly)
- NexGen and Park at similar air/fuel ratio
- NexGen burner higher heat release
- At 2000 degrees F, heat flux is 30% above upper bound (ISO 2685)


Burner Comparison – At 2000 F

- Heat flux of the NexGen burner is 30% higher than Park
- Park burner is observed to be more severe from a burn-through perspective

Heat Flux Comparison - 2000 F





Burn Through Comparison - 2000 F



- Park burner 1994 degrees F (@ 2.3 gph fuel)
- NexGen burner 2011 degrees F (@2.7 gph fuel)

Burner Comparison – At 2.15 gph

- Heat flux between both burners is similar (Park 15% higher than NexGen)
- Park burn-through is observed to be significantly more severe at similar fuel flow rate




- Park burner 1955 degrees F
- NexGen burner 1847 degrees F

Observations


- Park flame less uniform than NexGen
- NexGen flame hottest on outer edges; Park burner intensity peaks in the center

$$\frac{T_{max} - T_{min}}{T_{mean}} = 18\% \text{ (Park)}, 7\% \text{ (NexGen)}$$

	TC1 (F)	TC2 (F)	TC3 (F)	TC4 (F)	TC5 (F)	TC6 (F)	TC7 (F)	Average T (F)
Park:	1799	1938	2120	2167	2117	2006	1809	1994
Normalized Park:	90	97	106	109	106	101	91	
NexGen:	2056	1984	1948	1948	1992	2085	2093	2015
Normalized NexGen:	102	98	97	97	99	103	104	



Typical NexGen Temp. Map



Burn Through

- Temperature distribution is reflected in burn-through results
- Park burns through in the center where peak flame intensity resides
- NexGen burn through more uniform



Park Burner



NexGen Burner

Conclusions

- 2000 degree F min. average requirement, calibrated by 1/8" TC, drives heat flux up to and above ISO 2685 upper bound
 - Use 1/16" TCs to calibrate, or
 - Re-assess 'minimum average' temperature requirement
- Park vs NexGen Burners
 - Park burner is operated at lower BTU (lower air and fuel rate)
 - More non-uniform temperature distribution of Park burner; high center temperature
 - Burn through patterns are different
 - Park burner has shorter burn through time
- High non-uniform and high center temperature profile of Park burner may be the root cause for shorter burn through time